



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:
HARNETT CO ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BLVD

Name of System:
MICHAEL CHISEK

LILLINGTON, NC 27546
EIN:566000306EH

COURIER #: 14-73-01

SR 1510 MATTHEWS MILL POND RD
ANGIER, NC 27501

StarLiMS Sample ID: **ES100714-0107001**



Collected: 10/06/2014 11:00

Received: 10/07/2014 08:14

James E Manhart III

Angela Heybroek

ES Microbiology ID:

GPS Number:

Sample Source: **New Well**

Sampling Point: **Well head**

Well Permit Number:

11-5-27563R

27536R

Sample Description:

Comment:

Environmental Microbiology - Colisure Profile

Method: SM 9223B

Test Name: Water - Colisure

Analyte	Test Result	Analyst	Date
Total Coliform, Colisure	Absent	Darneice Owens	10/08/2014
<i>E. coli</i> , Colisure	Absent	Darneice Owens	10/08/2014

Report Date: 10/09/2014

Reported By: Cindy Price

Cindy Price

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.