HTE#_//- 5- 275-46 Harnett County Department of Public Health

Improvement Permit

26754

A building permit cannot be issued with only an Improvement Permit ISSUED TO: Stephenson Builders Inc SUBDIVISION Mc Dougald Place Site Improvements required prior to Construction Authorization Issuance: Proposed Wastewater System Type: 25% Reduction System Projected Daily Flow: 360 GPD Number of bedrooms: 3 Number of Occupants: 6 max Basement Yes Five years Permit valid for: □ No expiration Permit conditions: site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1954, .1955, .1955, .1955, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Stephenson Boilder Inc.

PROPERTY LOCATION: McDougeld Ld.

SUBDIVISION McDougeld Place LOT # 7

Facility Type: SFD New Expansion Repair Facility Type: SUBDIVISION New Expansion
Basement? Yes No Basement Fixtures? Yes No Basement? Yes No Basement Fixtures? No No

Type of Wastewater System** 25% Ned oct: On System (Initial) Wastewater Flow: 360 GPD (See note below, if applicable \square) 25% Reduction System (Repair) Installation Requirements/Conditions Exact length of each trench 230 feet Trench Spacing: 9 Feet on Center Trenches shall be installed on contour at a Soil Cover: 6-12 inches Septic Tank Size ______ gallons Pump Tank Size _____ gallons Maximum Trench Depth of: /2 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: _____ ft. TDH vs. ____ GPM _____ inches below pipe Conditions: Septic installer to call prior to installing system

Aggregate Depth: _______ inches above pipe
because of ditch depth _______ inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **|f applicable: / understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date: 9 68 2016

Harnett County Department of Public Health Site Sketch

ISSUED TO: Stephenson Boilder, Inc. PROPERTY LOCATON: McDougald Rd.

Authorized State Agent: Luya Marin, fetts

Date: 9/28/2011

