HTE#\_//-5-27580

## Harnett County Department of Public Health

## **Improvement Permit**

26757

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: Tingen Rd. ISSUED TO: Stancil Builders, Inc. SUBDIVISION Pattons Point LOT # 125 NEW 

REPAIR 

EXPANSION 

Type of Structure: 

FD 52 x 45′ Site Improvements required prior to Construction Authorization Issuance: Proposed Wastewater System Type: 25 To Reduction System Projected Daily Flow: 360 GPD 3 Number of Occupants: 6 max Number of bedrooms: Basement Yes Pump Required: 

Yes 

No 

May be required based on final location and elevations of facilities Five years Permit valid for: Permit conditions: ☐ No expiration Authorized State Agent: Dryn Milwing REH Date: SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance ISSUED TO: Staril Builders Inc.

PROPERTY LOCATION: Tingented.

SUBDIVISION Patters Point LOT # 125 SUBDIVISION \_ Patters
\_\_\_\_\_\_ New 
Expansion 
Repair Basement Fixtures? 
Yes No

25 % Leduct in System (Initial) Wastewater Flow: 
T60 GPD Basement? Yes Type of Wastewater System\*\* (See note below, if applicable □) 257 Reduct: un System (Repair)
Number of trenches 3 Installation Requirements/Conditions Number of trenches \_\_\_\_\_\_ feet Trench Spacing: \_\_\_\_\_ Feet on Center Septic Tank Size / OOO gallons Soil Cover: 24-6 inches Pump Tank Size \_\_\_\_\_ gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 36-18 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_ft. TDH vs. \_\_\_\_ GPM inches below pipe Aggregate Depth: \_\_\_\_\_\_ inches above pipe Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Sup Mining REHS

Construction Authorization Expiration Date: 9/29/2016

## Harnett County Department of Public Health Site Sketch

PROPERTY LOCATON: Tingen Rd.	
ISSUED TO: Stane: Builders Fac SUBDIVISION Pattons Point	LOT # 125
Authorized State Agent: Sugar Morin, REHS Date: 9/29/2	a/l

