

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy:

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Permit Numbers

Name: Yang, Bernard

Building: _____

Electrical: _____

Address: 146 Old Stage N.

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Date: 1-18-12

Building Official: _____

4-50027637
K. [Signature]

PREPARED 1/17/12, 14:06:29
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 25
DATE 1/18/12

ADDRESS : 146 OLD STAGE RD N SUBDIV:
CONTRACTOR : LANGDON L.M. PHONE : (919) 422-6946
OWNER : YOUNG BERNARD F PHONE : (919) 796-0560
PARCEL : 07-0680- - -0153- -07-
APPL NUMBER: 11-50027637 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 10/03/2011 02:00 PM JBROCK ----
TAKE 210 TO SHERIFF JOHNSON RD TO OLD
STAGE RD TURN RGIHT LOT ON LEFT LOY 3
PRE # 13346312

STRUCTURE: 000 000 64.6X46 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/02/11	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002156198
	11/02/11	AP	T/S: November 02, 2011 10:24 AM BSUTTON -----
A814 01	11/08/11	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002158822
	11/08/11	AP	T/S: 11/07/2011 01:48 PM VBROWN ----- 146 OLD STAGE RD N LOT 3 LILLINGTON 25746 T/S: 11/08/2011 01:38 PM TWARD -----
B103 01	11/08/11	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002158814
	11/09/11	AE	T/S: 11/07/2011 01:48 PM VBROWN ----- T/S: 11/09/2011 07:31 AM KSLATTUM ----- Projection missing at inside wall right side for about 6 feet. Ok to inspect at open floor.
B105 01	11/10/11	KS	R*OPEN FLOOR TIME: 17:00 VRU #: 002159432
	11/14/11	AP	T/S: 11/08/2011 04:09 PM VBROWN ----- T/S: 11/14/2011 08:18 AM KSLATTUM -----
R425 01	11/29/11	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002165355
	11/29/11	DA	T/S: 11/28/2011 10:38 AM VBROWN ----- T/S: 11/29/2011 02:23 PM KSLATTUM ----- 1. Girder truss requires 1618 pounds on one end and 900 on the other. 2. Sleeve drain thru foundation. 3. Re check hurricane ties for nails. Many missing. OK to side and insulate.
I129 01	12/01/11	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002166577
	12/01/11	AP	T/S: 11/30/2011 11:32 AM VBROWN ----- T/S: 12/01/2011 12:50 PM KSLATTUM -----
R425 02	12/01/11	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002166585
	12/01/11	AP	T/S: 11/30/2011 11:33 AM VBROWN ----- T/S: 12/01/2011 12:50 PM KSLATTUM -----
H824 01	12/20/11	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002175271
	12/20/11	AP	T/S: 12/21/2011 09:01 AM SZIMMER ----- T/S: 12/21/2011 09:02 AM SZIMMER -----
R429 01	1/18/12	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002182160

1-18 AP

----- COMMENTS AND NOTES -----