

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility:                      Design Flow (.1949): 360  $\frac{gpd}{ft^2}$   
 Location of Site:                      Property Recorded:                      Property Size:  
 Water Supply:                       Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-10	0-15	G SL	VFL NS/NP					
		15-31	SBK CL	F2 S/S/P	10YR 7/1 @ 31"				PS .45
2		0-17	G SL	VFL NS/NP					
		17-34"	SBK CL	F2 S/S/P	10YR 7/1 @ 34"				PS .5
3		0-24"	G SL	VFL NS/NP					
		24-36"	SBK CL	F2 S/S/P	10YR 7/1 @ 34"				PS .5
4		0-6"	G SL	VFL NS/NP					
		6" ~	SBK CL	F2 S/S/P	10YR 7/1 @ 18"				US

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: CX Others Present: BM
Available Space (.1945)	✓	✓	
System Type(s)	8' imp 2.5'		
Site LTAR	.45	.25	