

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: *Kurim*  
 Address: *3rd St*  
 Proposed Facility: *Paint Shop*  
 Location of Site: *Paint Shop*  
 Water Supply:  Public  Individual  Well *100'*  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed  
 Date Evaluated: *10-18-17-21-24*  
 Design Flow (.1949):  
 Property Recorded:  
 Property Size:  Spring  Other

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 20%	0-19	SL-LS	CL GR NSNP					
		18-42	SC	CL GR NSNP	42" 7.5m				.35
2	L 15	0-15	LS	CL GR NSNP					
		15-30	SL-CL	CL GR NSNP	WET AT surface				—
3	L 22	0-18	SL	CL GR NSNP					
		18-42	SC-CL	CL GR NSNP	40" 2.5m				.35
4	L 25	0-14	SL-LS	CL GR NSNP					
		14-30	SC-CL	CL GR NSNP	30" 7.5m				.3
5	L 25	0-16	SL	CL GR NSNP					
		16-36	SL-CL	CL GR NSNP	32" 7.5m				.3
6	L 22	0-10	SL	CL GR NSNP					
		10-30	SL-CL	CL GR NSNP	36" 7.5m				.3
7	L 20%	0-18	SL	CL GR NSNP					
		18-48	SC-CL	CL GR NSNP	42" 7.5m				.35 → 4
8/9	L-F-File	0-20	SL						
		20-40	SC-CL		8-28-36" 2.9m				.3

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Site Classification (.1948):
System Type(s)	<i>not 25%</i>	<i>not 25%</i>	Evaluated By: <i>[Signature]</i>
Site LTAR	<i>3-3</i>	<i>3-2-25</i>	Others Present: <i>[Signature]</i>