

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: \_\_\_\_\_ Applicant: \_\_\_\_\_ Date Evaluated: 11-29-11  
 Address: \_\_\_\_\_ Design Flow (.1949): 360  
 Proposed Facility: SFD + Pool + Garage Property Recorded: 12-1-12-11  
 Location of Site: \_\_\_\_\_ Property Size: 10+  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2,3	L-N	0-5	Rocks	variable to	Red				
4	L-N <sup>70%</sup>	0-4	SL	FR GN NSNP					
		4-30	SC-clay	FR 1 <sup>m</sup> SBK S.P.					
		30"+	SC-SAP mix	FR 1 <sup>m</sup> SBK S.P.		30"			.3
5	L-7%	0-14	SL	FR GN NSNP					
		14-26	SC-clom	FR 1 <sup>m</sup> SBK S.P.					
		26"+	SC-clom/SAP	FR 1 <sup>m</sup> SBK S.P.		26"			.25-.3
PETS 6	L-70%	0-15	SL	FR GN NSNP					
		15-44	SC clay	FR 1 <sup>m</sup> SBK S.P.		42" - SAP			.3
7	EN-6%	0-16	SL	FR GN NSNP					
		16-42	SC-clay	FR 1 <sup>m</sup> SBK S.P.	90"	40			.3
8	LN 5-7%	0-15	SL	FR GN NSNP					
		15-44	SC-cl	FR 1 <sup>m</sup> SBK S.P.	44	44			.3
9	L-5-	0-18	SL	FR GN NSNP					
		18-30	SC-clay		24"	24"			.25

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	25-22	25-22	
Site LTAR	.3	.3	