

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: _____
 Address: _____
 Proposed Facility: *SFD Rebuild* Date Evaluated: _____
 Location of Site: *301 - Pass* Design Flow (.1949): *480*
 Water Supply: _____ Property Recorded: _____
 Evaluation Method: Auger Boring Public Individual Well Spring Other
 Type of Wastewater: Sewage Pit Cut Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 2%	0-8	SL						
		8-44	SC Clay		40"				.4
2	L 2%	0-10	SL						
		10-40	SC-Clay		38"				.4
3	L 2%	0-7	SL						
		7-40	SC Clay		34-36				.35
4	L 2%	0-7	SL						
		7-42	SC-Clay		38-40"				.4
5	L 2%	0-10	SL						
		10-42	SC-Clay		36"				.4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>PS</i> Others Present: <i>2</i>
Available Space (.1945)			
System Type(s)	<i>280</i>		
Site LTAR			