

Improvement Permit

26746

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: DEANA MANNING REALTY PROPERTY LOCATION: McDOUGAL RO
WYNN CONSTRUCTION INC SUBDIVISION SUMMERHILL LOT # 3

NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: 360 (66'x28') (50'x50')

Proposed Wastewater System Type: CONVENTIONAL 25% REDUCTION

Projected Daily Flow: 360 480 GPD

Number of bedrooms: 34 Number of Occupants: 68 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well 100 feet

Permit conditions: _____ Permit valid for: Five years No expiration

Authorized State Agent: REHS Date: 12/7/11 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

REHS REHS

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: DEANA MANNING REALTY PROPERTY LOCATION: McDOUGAL RO
WYNN CONSTRUCTION INC SUBDIVISION SUMMERHILL LOT # 3

Facility Type: SFD (66'x28') (50'x50') New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** CONVENTIONAL 25% REDUCTION (Initial) Wastewater Flow: 480 360 GPD
 (See note below, if applicable 25% REDUCTION CONVENTIONAL (Repair))

Installation Requirements/Conditions

Number of trenches 3

Septic Tank Size 1000 gallons Exact length of each trench 100 feet Trench Spacing: 9 Feet on Center

Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches

Pump Requirements: _____ ft. TDH vs. _____ GPM Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)

Aggregate Depth: 6 inches below pipe 2 inches above pipe 12 inches total

Conditions: _____

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: REHS Date: 12/7/11
REHS Construction Authorization Expiration Date: 12/7/16

HTE# 11-5-27959R

Permit # 26746

Harnett County Department of Public Health Site Sketch

~~DEANA MANNING REALTY~~

PROPERTY LOCATOR: McDOUGALD RD

ISSUED TO: ~~W. J. CONSTRUCTION INC~~ SUBDIVISION SUMMERHILL LOT # 3

Authorized State Agent: ~~REHS (OLIVER TOLKSDORF)~~ Date: 12/7/11

REVISED 5/19/14

McDOUGALD Rd

