

Improvement Permit

26746

Moss

A building permit cannot be issued with only an Improvement Permit

~~DEBRA MANNING REALTY~~

PROPERTY LOCATION: McDOUGAL RO

ISSUED TO: WYNN CONSTRUCTION INC

SUBDIVISION SUMMERHILL

LOT # 3

NEW

REPAIR

EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: 350 (66'x48') (50'x50') (55'x39')

Proposed Wastewater System Type: CONVENTIONAL 25% REDUCTION

Projected Daily Flow: 362 GPD GPD 360

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well 100 feet

Permit valid for: Five years No expiration

Permit conditions:

Authorized State Agent:

RENS

Date: 12/7/11

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

REVISO 5/19/14

RENS REISSO 7/15/15

RENS

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: WYNN CONSTRUCTION INC

PROPERTY LOCATION: McDOUGAL RO

SUBDIVISION SUMMERHILL

LOT # 3

Facility Type: SFD (66'x48') (50'x50') New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** CONVENTIONAL 25% REDUCTION (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable) CONVENTIONAL 25% REDUCTION (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Pump Tank Size _____ gallons

Number of trenches 3

Exact length of each trench 100 75 feet

Trenches shall be installed on contour at a Maximum Trench Depth of: 18 inches

(Trench bottoms shall be level to +/-1/4" in all directions)

Trench Spacing: 9 Feet on Center

Soil Cover: 6 inches

(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: 5 inches below pipe

2 inches above pipe

12 inches total

Conditions: _____

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____

Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent:

RENS

Date: 12/7/11

REVISO 5/19/14

Construction Authorization Expiration Date: 12/7/16

HTE# 11-5-27959RRR

Permit # 26746

Harnett County Department of Public Health Site Sketch

DEANA MANNING REALTY

PROPERTY LOCATOR: McDOUGALD Rd

ISSUED TO: ~~WATER CONSTRUCTION INC~~

SUBDIVISION SUMMERHILL

LOT # 3

Authorized State Agent:

~~REHS (OLIVER TOLKSDORF)~~ Date: 12/7/11

REVISED 5/19/14

~~REHS~~

REVISED 7/15/15

~~REHS~~

McDOUGALD Rd

