

Revised 1/12/12

SOUTHEASTERN SOIL & ENVIRONMENTAL ASSOC, INC.

PROPOSED SUBSURFACE WASTE DISPOSAL SYSTEM DETAIL SHEET

SUBDIVISION Summer Hill

LOT 4

INITIAL SYSTEM pump to approved 25% reduction

REPAIR pump to approved 25% reduction

DISTRIBUTION serial

DISTRIBUTION serial

BENCHMARK 100.0

LOCATION front corner 3/4

NO. BEDROOMS 3

initial proposed LTAR = 0.35 gpd/ft²
repair " " = 0.4 gpd/ft²

<u>LINE</u>	<u>FLAG COLOR</u>	<u>ELEVATION</u>	<u>ACTUAL LENGTH</u>
-------------	-------------------	------------------	----------------------

Initial

1	P	97.17	35'
2	Y	96.84	48'
3	P	96.50	70'
4	Y	95.72	60'
5	P	95.63	50'
			263'
6	Y	95.34	40'
7	P	95.17	40'
8	Y	95.08	40'
9	P	95.00	35'
10	Y	94.91	35'
11	P	94.67	35'
			223'

BY M. FAJER

DATE

Typical Soil Profile

0-10 USAN9 (VF, wg-)
10-36+ SEC. (F. S&C)
C-2 7 3/4"

Install at 18 inches (initial)

Southeastern Soil & Environmental Associates, Inc.

P.O. Box 9321
Fayetteville, NC 28311
Phone/Fax (910) 822-4540
Email mike@southeasternsoil.com

Summer Hill
Lot 4
PROPOSED LAYOUT

