

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address:

Proposed Facility: 3 bedrooms

Date Evaluated:

Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public Individual Well

Spring Other

Evaluation Method: Auger Boring

Pit Cut

Type of Wastewater:

Sewage Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941		.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy					
1	L5 5-10%	0-18"	G SL	VF2 NS/NP					S.6
2		0-18"	G SL	VF1 NS/NP					
		18-36"	SBX SCL	FR SS/SP	10/12-7/20 28"				PS .45
3		0-48"	G SL	VF2 NS/NP					S.6

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: CS Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	25/11	RVW 25/10	
Site LTAR	.6	.45	

1x200' @ 18' 24'