

ADDRESS : 446 SPRING FLOWERS DR
 CONTRACTOR : CUMBERLAND HOMES INC
 OWNER : CRESTVIEW DEVELOPMENT LLC
 PARCEL : 09-9567-02- -0006- -26-
 APPL NUMBER: 11-50028018 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 12/08/2011 10:20 AM JBROCK ----
 TAKE 27 W FROM LILLINGTON TURN RIGHT ON
 JOHNSONVILLE SCHOOL RD TURN RIGHT ON
 PONDEROSA RD L INTO S/D R ON FERN RIDGE
 L ON SPRING FLOWERS DR LOT ON RIGHT LOT
 27

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
 PHONE : (910) 892-4345
 PHONE :

STRUCTURE: 000 000 49X47 4BDR SLAB W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00
 SEPTIC - EXISTING? : NEW TANK
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/13/12	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002181061
	1/13/12	AP	T/S: 01/13/2012 06:13 PM FSPIVEY -----
B103 01	1/23/12	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002184120
	1/23/12	AP	T/S: 01/23/2012 01:07 PM MREARIC -----
A814 01	1/26/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002184139
	2/01/12	AP	446 spring flowers dr lot 27 cameron 28326----- T/S: 02/01/2012 08:35 AM TWARD -----
P309 01	2/01/12	FS	R*PLUMB UNDER SLAB VRU #: 002187537
	2/01/12	AP	T/S: 02/01/2012 03:12 PM FSPIVEY -----
B111 01	2/02/12	FS	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002188464
	2/02/12	AP	T/S: 02/02/2012 03:49 PM FSPIVEY -----
R425 01	4/09/12	DT	FOUR TRADE ROUGH IN VRU #: 002212876
	4/09/12	DA	T/S: 04/09/2012 10:56 AM DETAYLOR ----- Need nail guards for hvac line sets throughout home Anchor bolts in garage missing nuts Need 10 psi on gas line Repair hole in top plate in laundry room Fire block gap in dining room b/w top plate and trey Okay to side, do not insulate
R425 02	4/11/12	DT	FOUR TRADE ROUGH IN VRU #: 002213848
	4/11/12	DA	T/S: 04/11/2012 09:53 AM DETAYLOR ----- HVAC line sets still missing nail guards and caulk Okay to insulate
I129 01	4/13/12	DT	R*INSULATION INSPECTION VRU #: 002214874
	4/13/12	AP	T/S: 04/13/2012 09:16 AM DETAYLOR -----
R425 03	4/13/12	DT	FOUR TRADE ROUGH IN VRU #: 002214865
	4/13/12	AP	T/S: 04/13/2012 09:16 AM DETAYLOR -----
H824 01	5/01/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002222644
	5/01/12	AP	T/S: 05/02/2012 09:07 AM SZIMMER ----- T/S: 05/02/2012 09:07 AM SZIMMER -----
R431 01	5/29/12	FS	FOUR TRADE FINAL >2500 VRU #: 002231777
	5/29/12	DA	T/S: 05/29/2012 03:10 PM FSPIVEY ----- insulation in attic cover on vent on back of house
R429 01	6/01/12	TI	FOUR TRADE FINAL VRU #: 002233498

ADDRESS : 446 SPRING FLOWERS DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : CRESTVIEW DEVELOPMENT LLC
PARCEL : 09-9567-02- -0006- -26-
APPL NUMBER: 11-50028018 CP NEW RESIDENTIAL (SFD)

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
PHONE : (910) 892-4345
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
--------	------------------------	----------------	---------------------------------

AP 6-1-12

COMMENTS AND NOTES

FS