

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address:
 Proposed Facility:
 Location of Site:
 Water Supply:
 Evaluation Method: Auger Boring
 Type of Wastewater: Sewage

Date Evaluated:
 Design Flow (.1949): 170 GPD
 Property Recorded:
 Public Individual Well Spring Other
 Pit Cut Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 25%	0-12"	G SL	VFA NS/NP					
		12-24"	SBX SCL	FR SS/NR					PS .45
2		0-8"	FILL						
		9-36"	SBX SCL	FR SS/NR					PS .4
3		0-6"	G S	VFA NS/NP					
		16-40"	SBX SCL	FR SS/NP					PS .45
4		0-10"	FILL						
		10" ⁺⁺	SBX SCL	FR SS/SP	101R7/2e 22"				65

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>PS</u> Evaluated By: <u>OT</u> Others Present: <u>1</u>
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<u>25% RPO</u>		
Site LTAR	<u>.45</u>	<u>.4</u>	

3-90" @ 24"