

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address: *SFR*

Date Evaluated: *1-12-12*

Proposed Facility:

Design Flow (.1949): *438*

Location of Site:

Property Recorded:

Property Size:

Water Supply:

Public  Individual  Well

Spring  Other

Evaluation Method:  Auger Boring

Pit  Cut

Type of Wastewater:

Sewage  Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>L 1%</i>	0-12	<i>CLM</i>	<i>FLGLOSSY</i>					
		12-40	<i>CLM</i>	<i>FM 15% S.P.</i>	<i>36" 5M 3.2</i>				<i>.3</i>
2	<i>L 3%</i>	0-12	<i>CLM</i>	<i>SL w FM 50% S.P.</i>	<i>12" 7.5M</i>				
3	<i>L 3%</i>	0-12	<i>CLM</i>	<i>FM 15% S.P.</i>	<i>12"</i>				<i>.2</i>
4	<i>L 3%</i>	0-12	<i>SL</i>	<i>SL w FM 50% S.P.</i>					
		12-40	<i>SL-CLM</i>	<i>FM 15% S.P.</i>	<i>34-36" 5M 3.2</i>				<i>.3</i>
5	<i>L 3%</i>	0-10	<i>SL</i>	<i>SL w FM 50% S.P.</i>	<i>30" 7.5M 3.2</i>				<i>.25</i>
		10-34	<i>SL-CLM</i>	<i>FM 15% S.P.</i>					
6+7	<i>L 2.5%</i>	0-12	<i>SL</i>	<i>SL w FM 50% S.P.</i>					
		12-36	<i>SL-CLM</i>	<i>FM 15% S.P.</i>	<i>30-32" 7.5M 3.2</i>				<i>.25</i>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: Others Present:
Available Space (.1945)			
System Type(s)	<i>35</i>	<i>25</i>	
Site LTAR	<i>.25</i>	<i>.25</i>	