

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: Wyuu Const

Building: 12-50028150

Address: 294 Horse Whisperer

Electrical: 11

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: 11

Date: 6-12-12

Building Official: T. Michael Pearson

ADDRESS : 294 HORSE WHISPERER LN
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : HARNETT DEVELOPERS LLC
PARCEL : 03-0507- - -0200- -35-
APPL NUMBER: 12-50028150 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 01/10/2012 10:01 AM JBROCK ----
27 W TO DOCS RD LEFT ON DOCS RD S/D
WILL BE ON THE RIGHT LOT 91

SUBDIV: TROTTERS RIDGE PH1C 21LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 56X66 4BDR MONO W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 4000000.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	4/03/12	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002210706
	4/03/12	AP	T/S: 04/02/2012 01:21 PM VBROWN ----- T/S: 04/03/2012 11:53 AM MREARIC -----
A814 01	4/04/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002211225
	4/05/12	AP	T/S: 04/03/2012 10:54 AM VBROWN ----- 294 HORSE WHISPERER LN LOT 91 LILLINGTON 27546- T/S: 04/05/2012 10:29 AM TWARD -----
B111 01	4/04/12	MR	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002211217
	4/04/12	AP	T/S: 04/03/2012 10:54 AM VBROWN ----- T/S: 04/04/2012 12:26 PM MREARIC -----
R427 01	4/27/12	MR	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002219731
	4/27/12	AP	T/S: 04/25/2012 12:40 PM VBROWN ----- T/S: 04/27/2012 11:10 AM MREARIC ----- dryer=33'
I129 01	5/01/12	MR	R*INSULATION INSPECTION VRU #: 002221075
	5/01/12	AP	T/S: 05/01/2012 12:13 PM MREARIC ----- R-15, R-38
H824 01	5/16/12	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002228112
	5/17/12	AP	T/S: 05/17/2012 09:05 AM SZIMMER ----- T/S: 05/17/2012 09:07 AM SZIMMER -----
R431 01	6/07/12	MR	FOUR TRADE FINAL >2500 VRU #: 002236339
	6/07/12	DP	T/S: 06/07/2012 12:44 PM MREARIC -----
R431 02	6/12/12	TI	light in closet too close insulation in attic not installed right FOUR TRADE FINAL >2500 VRU #: 002238046
	6-12-12	AP-MR	Premise number is 53155269

COMMENTS AND NOTES

Light Removed and blanked off