

PREPARED 5/01/12, 14:10:20
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 16
DATE 5/02/12

ADDRESS : 241 HORSE WHISPERER LN
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : HARNETT DEVELOPERS LLC
PARCEL : 03-0507- - -0200- -40-
APPL NUMBER: 12-50028153 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 01/10/2012 10:01 AM JBROCK ----
27 W TO DOCS RD LEFT ON DOCS RD S/D
WILL BE ON THE RIGHT LOT 96

SUBDIV: TROTTERS RIDGE PH1C 21LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 49X57 4BDR MONO W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00
SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	4/30/12 4/30/12	DT AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002221067 T/S: 04/27/2012 12:39 PM VBROWN ----- T/S: 04/30/2012 11:32 AM DETAYLOR -----
B114 01	5/02/12 <u>5-2-12</u>	TI <u>AP MP</u>	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002222115
A814 01	5/02/12 5/01/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002222107 241 HORSE WHISPERER LN LOT 96 LILLINGTON 27546 T/S: 05/01/2012 08:35 AM TWARD -----

COMMENTS AND NOTES

Waiting on Res-check
Slab-R-O

~~17166938~~

Rec'd. Eng. on 5/06

2-9-12
3848
900
11/12

DAVID MILLER, PE
6300 Creedmoor Rd, STE 170#363
Raleigh, NC 27612
(919) 422-8932 (Office) ; DAVE@DMA-PA.COM

April 27, 2012

WYNN CONSTRUCTION
2550 CAPITAL DRIVE
SUITE 105
CREEDMOOR, NC 27522

E mailed to: jason@wynnconstruct.com

RE: Engineering – Field Observation
Lot 96 Trotters Ridge Subdivision
Lillington, Harnett County, NC ; Permit No.: 12-50028153
Job No.: 12DDM-0427A

To whom it may concern/ Inspections Dept.:

The undersigned arrived on-site to observe and test the in-place fill conditions for the above referenced site. Based on the testing (Per ASTM Special publication 399) the fill materials (Tan silty sands (Unified Soil Classification System – SM)) were adequately compacted (95% Standard Proctor) and adequate to support the planned structure. Based on the observations and testing the bearing soils for the footings will provide adequate support.

Sincerely,

David Miller, PE

DEM/12DDM-0427A

