

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address: Date Evaluated: 11/20/12, 23, 24

Proposed Facility: 4 SEED ROOMS Design Flow (.1949): 480 gpd Property Size:

Location of Site: Property Recorded:

Water Supply: Public Individual Well Spring Other

Evaluation Method: Auger Boring Pit Cut

Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 0-2°/10	0-18	G SL	VFR NS/NP					
		18-43	SBR SCL	FR SS/SP	MATRIX 10YR 5/4				PS 4
		43-48	G S	VFR NS/NP					
2		0-18	G LS	VFR NS/NP					
		18-28	SBR SCL ^Y	FR SS/SP					PS 5
		28-48	G LS	VFR NS/NP					
3		0-48	G S	VFR NS/NP					5B

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: -
Available Space (.1945)	✓		
System Type(s)	2 5/8" PVC	PUMP TO PIPES	
Site LTAR	4	1	