

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address: 4850200m

Date Evaluated: 1/20/20, 23/24

Proposed Facility: 4850200m

Design Flow (.1949): 480 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public Individual Well

Spring Other

Evaluation Method: Auger Boring

Pit Cut

Type of Wastewater:

Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 0-2% 10	0-23	G SL	VFA NS/NP					
		23-43	SX SCL	FR/SS/K	10R71 C40"				PS .4
2		0-18	C LS	VFA NS/NP					
		18-30	SX SCL	FR SS/NP					PS .4
		30-48	G S	VFA NS/NP					
3		0-25	G S	VFA NS/NP					S.R

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OX Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	25' 20"	ABPS (FWD)	
Site LTAR	.4	.8	