

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address: 4 EEDONONS

Date Evaluated: 1/20/12, 23, 24

Proposed Facility: 4 EEDONONS

Design Flow (.1949): 1200 GPD

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public Individual Well

Spring Other

Evaluation Method: Auger Boring

Pit Cut

Type of Wastewater:

Sewage Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L5 0-26	0-23	G SL	VFA 15/MP					
		23-36	SBX SL	F2 SS/MP					PS 4
		36-41	G SL	VFA 15/MP					
		41-48	G S	VFA 15/MP					
2		0-26	G S	VFA 15/MP					
		26-36	G LS	VFA 15/MP					
		36-48	G S	VFA 15/MP					S.R
3		0-48	G S	VFA 15/MP					S.R

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: [Signature]
Available Space (.1945)			
System Type(s)	25% [Signature]	PPR [Signature]	
Site LTAR	12	8	