

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address: Proposed Facility: 3 Bldg.com

Date Evaluated: 1/30/12
 Design Flow (.1949): 3000

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public Individual Well

Spring Other

Evaluation Method: Auger Boring

Pit Cut

Type of Wastewater:

Sewage Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS cekc	0-10"	G S	VFR NS/HP					
		10-24"	SBR SCL	FR SS/SP	10" R 7/2 @ 1"				US
2	LS 0-2 1/2 CVCY	0-12"	G LS	VFR NS/HP					
		12-20"	SBR SCL	FR SS/SP					PS .5
		20-24"	G S	VFR NS/HP					
3		0-16"	G LS	VFR NS/HP					
		16-24"	SBR SCL	FR SS/SP					PS .5
		24-28"	G S	VFR NS/HP					
4		0-14"	G LS	VFR NS/HP					
		14-28"	SBR SCL	FR SS/SP					PS .5
		28-46"	G S	VFR NS/HP					
5		0-28"	G LS	VFR NS/HP					
		28-30"	SBR SCL	FR SS/SP					PS .5
		30-32"	G S	VFR NS/HP					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): P< Evaluated By: OX Others Present: -
Available Space (.1945)			
System Type(s)	PUMP 25' / 10'		
Site LTAR	.5	.5	

2x100 @ 30-34" START @ 2' 30"