

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:**       X       **Occupancy:**       X      

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification:       R-3      

Name:       H + H Constructors, Inc.      

Address:       57 Fernwood Pl.      

**Permit Numbers**

Building:       12-50028201      

Electrical:                   11      

Insulation:                   11      

Plumbing:                   11      

Mechanical:                   11      

MFG Home:                               

Date:       12-10-13      

Building Official:       T. Michael Reavis

ADDRESS : 57 FERNWOOD PL SUBDIV: OAKMONT PHASE 1 SECT1  
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
 OWNER : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
 PARCEL : 03-0507- - -0046- -11-  
 APPL NUMBER: 12-50028201 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 01/18/2012 09:56 AM JBROCK ----  
 TAKE HWY 27 TO DOCS RD TURN LEFT GO  
 ABOUT 1.5 MILES TURN LEFT TO S/D LOT 11

**STRUCTURE: 000 000 59.3X50 5BDR SLAB W/ GARAGE**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 5000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	3/20/13 3/22/13	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002354025 57 FERNWOOD PL LILLINGTON 27546----- T/S: 03/22/2013 01:16 PM TWARD -----
B101 01	3/20/13 3/20/13	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002354033 T/S: 03/20/2013 01:24 PM MREARIC -----
B103 01	3/25/13 3/25/13	FS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002356129 T/S: 03/25/2013 02:52 PM FSPIVEY -----
P309 01	4/04/13 4/04/13	MR DA	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002361129
P309 02	4/05/13 4/05/13	MR AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002361947 T/S: 04/05/2013 01:40 PM MREARIC -----
B111 01	4/10/13 4/10/13	MR DA	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002364313 T/S: 04/10/2013 01:05 PM MREARIC ----- no res-check... no inspection
B111 02	4/11/13 4/11/13	MR AP	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002364800 T/S: 04/11/2013 02:52 PM MREARIC -----
R425 01	5/17/13 5/17/13	MR DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002383826 T/S: 05/17/2013 01:59 PM MREARIC ----- no nuts
R425 02	5/20/13 5/20/13	MR DP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002384352 T/S: 05/20/2013 09:17 AM MREARIC -----
R425 03	5/22/13 5/22/13	MR AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002385730 T/S: 05/22/2013 01:11 PM MREARIC -----
I129 01	5/24/13 5/24/13	MR DA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002386944 T/S: 05/24/2013 01:20 PM MREARIC ----- insulation fallin down front bedroom has areathat must be batted rear left bedroom has one also
I129 02	5/28/13 5/28/13	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002387637 T/S: 05/28/2013 12:19 PM DETAYLOR -----
H824 01	6/17/13 6/17/13	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002398279 T/S: 06/18/2013 10:35 AM SSTEWARD ----- T/S: 06/18/2013 10:37 AM SSTEWARD -----
E209 01	7/29/13 7/29/13	MR DA	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002416964 T/S: 07/29/2013 01:06 PM MREARIC ----- 2 neutral wires under one screw
E209 02	8/07/13 8/07/13	MR AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002421915 T/S: 08/07/2013 01:56 PM MREARIC -----

PREPARED 12/09/13, 14:07:05  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 4  
DATE 12/10/13

-----  
ADDRESS : 57 FERNWOOD PL  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER : H & H CONSTRUCTORS INC  
PARCEL : 03-0507- - -0046- -11-  
APPL NUMBER: 12-50028201 CP NEW RESIDENTIAL (SFD)

SUBDIV: OAKMONT PHASE 1 SECT1  
PHONE : (910) 486-4864  
PHONE : (910) 486-4864

-----  
REQUESTED INSP DESCRIPTION  
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS  
-----  
R429 01 12/10/13 TI FOUR TRADE FINAL TIME: 17:00 VRU #: 002474336  
2 AP-HR

-----  
COMMENTS AND NOTES  
-----