

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant: *W. M. ...*  
 Address:                      Date Evaluated: *1-23-91*  
 Proposed Facility: *SFP*                      Design Flow (.1949):  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 4%	0-24	SL	FR GA					
		24-48	SL	FR (M) (S) (S) (S) (S) (S)	44" 7.5m 92				.4
2	L 4%	0-20	SL	FR GA NSWP					
		20-44	SCL	FR (M) (S) (S) (S) (S) (S)	42" 7.5m 92				.4
3	L 4%	0-20	S2	FR GA NSWP					
		20-44	SCL	FR (M) (S) (S) (S) (S) (S)	42" 7.5m 92				.4
4	L 4%	0-20	SL	FR GA NSWP					
		20-44	SCL	FR (M) (S) (S) (S) (S) (S)	42" 7.5m 92				.4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <i>PS</i> Others Present: <i>SL</i>
Available Space (.1945)			
System Type(s)			
Site LTAR			