

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address:
 Proposed Facility: Date Evaluated: 1-24-12
 Location of Site: Design Flow (.1949): 420
 Water Supply: Property Recorded: Property Size:
 Evaluation Method: Auger Boring Public Individual Well Spring Other
 Type of Wastewater: Sewage Pit Cut Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1+	L-4%	0-20	SL	FA GRNSWP					
		20-44	SCL	Am 1 ^m 5936 5558	36"	7.542	7.7		35
2	L-3 1/2%	0-24	SL	FA GRNSWP					
		24-48	SCL	Am 1 ^m 2224 3461	40"	7.22	3.2		.4
3	L-3%	0-24	S	FUGRNSWP					
		24-48	SCL	Am 1 ^m 5936 5558	42"	7.542	9.2		.4
4	L-2.3%	0-24	SL	FUGRNSWP					
		24-48	SCL	Am 1 ^m 5936 5558	42"	7.542	9.2		.4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: Others Present:
Available Space (.1945)		/	
System Type(s)	282	22	
Site LTAR	.4	.35-.4	