HIE# 17-2-98518

Harnett County Department of Public Health

Improvement Permit

26881

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: MARKS RD ISSUED TO: LARRY DRUGITERY SUBDIVISION CORES FARMS LOT # Site Improvements required prior to Construction Authorization Issuance: Type of Structure: SFO (56 X40 Proposed Wastewater System Type: Conventional Projected Daily Flow: 360 GPD Number of bedrooms: __________ Number of Occupants: ____ & max ⊠ No Basement 1 Yes Pump Required: □Yes ➤ No ☐ May be required based on final location and elevations of facilities Type of Water Supply:
Community X Public
Well Distance from well 100 feet Five years Permit valid for: Permit conditions: ☐ No expiration site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1954, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: LARRY DAUGHTRY PROPERTY LOCATION: MARKS (CD SUBDIVISION COOPER FARMS Facility Type: SFD (56 ~ 49) New 🗆 Expansion ☐ Repair Basement Fixtures?

Yes ______ (Initial) Wastewater Flow: 360 ____ GPD CONVENTIUNAL Type of Wastewater System** (See note below, if applicable CONVENTIONAL Number of trenches Installation Requirements/Conditions Trench Spacing: _____ Feet on Center Exact length of each trench 50 feet Septic Tank Size 1000 gallons Soil Cover: 12-22 inches Pump Tank Size _____ gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 24-36 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to $\pm \frac{1}{4}$ " 36" above the trench bottom) in all directions) Pump Requirements: ______ft. TDH vs. _____ GPM _____ inches below pipe Aggregate Depth: ______ inches above pipe inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation 11-the site plan, Page or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: _ Date:

Construction Authorization Expiration Date:

HTF#	12-	5-28218
------	-----	---------

Permit # 2688)

Harnett County Department of Public Health Site Sketch

	PROPERTY LOCATON: MARCES RED	
ISSUED TO: LARRY DAUCHTRY	SUBDIVISION COOPER FARENS	LOT # <u>\$</u>
Authorized State Agent:	REMS (OLIMER FOLKSONE) Date: 1/20/12	
110		

