

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: X **Occupancy:** V

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Name: Stanal Builders

Address: 182 Gunner Ct.

Permit Numbers

Building: 12-50028229

Electrical: .

Insulation: .

Plumbing: .

Mechanical: .

MFG Home: .

Date: 1-14-13

Building Official: T. MacLeod-Reavis

ADDRESS : 182 GUNNER CT SUBDIV: PATTONS POINT PH 2 73LOTS
 CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
 OWNER : STANCIL BUILDERS INC PHONE :
 PARCEL : 03-9597- - -0225- -28-
 APPL NUMBER: 12-50028229 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/24/2012 09:51 AM VBROWN ----
 182 GUNNER, PATTONS POINT #148. 27W,
 LEFT ON DOCS RD, RIGHT ON MICRO TOWER
 RD, SUB DIV ON RIGHT.

STRUCTURE: 000 000 42X38 3BDR 2BATH SFD W GAR, DECK, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/07/12	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002189811
	2/07/12	AP	T/S: 02/07/2012 10:58 AM DETAYLOR
A814 01	2/20/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002192852
	2/16/12	AP	182 GUNNER CT LOT 148 BROADWAY 27505- T/S: 02/16/2012 02:03 PM TWARD
B103 01	2/29/12	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 002198197
	2/29/12	AP	T/S: 02/29/2012 02:58 PM FSPIVEY
B105 01	9/21/12	MR	R*OPEN FLOOR VRU #: 002280980
	9/21/12	AP	T/S: 09/21/2012 12:39 PM MREARIC
H824 01	10/10/12	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002290187
	10/10/12	AP	T/S: 10/11/2012 10:42 AM SSTEWARD T/S: 10/11/2012 10:42 AM SSTEWARD
R425 01	10/12/12	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002290302
	10/12/12	DA	T/S: 10/12/2012 03:01 PM MREARIC no high volt and low volt allowed in same box brace gables sheathe wing-walls ok to side and insul.
I129 01	10/24/12	MR	R*INSULATION INSPECTION VRU #: 002294788
	10/24/12	DA	T/S: 10/24/2012 01:03 PM MREARIC air barrier behind showers
R425 02	10/24/12	MR	FOUR TRADE ROUGH IN VRU #: 002294751
	10/24/12	AP	VOICE MESSAGE LEFT T/S: 10/24/2012 01:04 PM MREARIC
I129 02	10/25/12	MR	R*INSULATION INSPECTION VRU #: 002295849
	10/25/12	AP	T/S: 10/25/2012 12:44 PM MREARIC
R429 01	1/10/13	MR	FOUR TRADE FINAL VRU #: 002325594
	1/10/13	CA	T/S: 01/10/2013 12:17 PM MREARIC
R429 02	1/14/13	TI	FOUR TRADE FINAL VRU #: 002326511

1-14-13 ~~DA~~
 AP-14R

COMMENTS AND NOTES

ADDRESS : 182 GUNNER CT
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : STANCIL BUILDERS INC
PARCEL : 03-9597- - -0225- -28-
APPL NUMBER: 12-50028229 CP NEW RESIDENTIAL (SFD)

SUBDIV: PATTONS POINT PH 2 73LOTS
PHONE : (919) 639-2073
PHONE :

CO
1-14-13

DIRECTIONS : T/S: 01/24/2012 09:51 AM VBROWN ----
182 GUNNER, PATTONS POINT #148. 27W,
LEFT ON DOCS RD, RIGHT ON MICRO TOWER
RD, SUB DIV ON RIGHT.

STRUCTURE: 000 000 42X38 3BDR 2BATH SFD W GAR, DECK, CRAWL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/07/12	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002189811
	2/07/12	AP	T/S: 02/07/2012 10:58 AM DETAYLOR -----
A814 01	2/20/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002192852
	2/16/12	AP	182 GUNNER CT LOT 148 BROADWAY 27505- T/S: 02/16/2012 02:03 PM TWARD -----
B103 01	2/29/12	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 002198197
	2/29/12	AP	T/S: 02/29/2012 02:58 PM FSPIVEY -----
B105 01	9/21/12	MR	R*OPEN FLOOR VRU #: 002280980
	9/21/12	AP	T/S: 09/21/2012 12:39 PM MREARIC -----
H824 01	10/10/12	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002290187
	10/10/12	AP	T/S: 10/11/2012 10:42 AM SSTEWARD ----- T/S: 10/11/2012 10:42 AM SSTEWARD -----
R425 01	10/12/12	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002290302
	10/12/12	DA	T/S: 10/12/2012 03:01 PM MREARIC ----- no high volt and low volt allowed in same box brace gables sheathe wing-walls ok to side and insul.
I129 01	10/24/12	MR	R*INSULATION INSPECTION VRU #: 002294788
	10/24/12	DA	T/S: 10/24/2012 01:03 PM MREARIC ----- air barrier behind showers
R425 02	10/24/12	MR	FOUR TRADE ROUGH IN VRU #: 002294751
	10/24/12	AP	VOICE MESSAGE LEFT T/S: 10/24/2012 01:04 PM MREARIC -----
I129 02	10/25/12	MR	R*INSULATION INSPECTION VRU #: 002295849
	10/25/12	AP	T/S: 10/25/2012 12:44 PM MREARIC -----
R429 01	1/10/13	TI	FOUR TRADE FINAL VRU #: 002325594

1-10-13 CA-MR

COMMENTS AND NOTES