

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address: Proposed Facility: 3 bedrooms

Date Evaluated: 1/31/12
 Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public Individual Well

Spring Other

Evaluation Method: Auger Boring

Pit Cut

Type of Wastewater:

Sewage Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS SS 2-5	0-3'	GS	VF2 NS/MP					
		31-36"	SBK SCL	F2 SS/SP					PS .5
			114R @	36" ROCK					
2		0-34"	GS	VF2 NS/MP					
		34-36"	SBK SCL	F2 SS/SP					PS .5
3		0-48"	GS	VF2 NS/MP					PS .5
4		0-6'	GS	VF2 NS/MP					
		6-8"	SBK C	F1 S/P					PS .3

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: -
Available Space (.1945)			
System Type(s)	PUMP & TREATMENT		
Site LTAR	.5	.8	

3x60' @ 24-30


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTLY STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE					
H-HEAD SLOPE	III	SI-SILT	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
CC-CONCLAVE SLOPE		SIL-SILT LOAM			
CV-CONVEX SLOPE		CL-CLAY LOAM			
T-TERRACE		SCL-SANDY CLAY LOAM			
FP-FLOOD PLAN	IV	SIC-SILTY CLAY C-CLAY SC-SANDY CLAY	0.4 - 0.1		

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)



**ELIMINARY PLAT
FOR RECORDATION
REVENUES OR SALES**

SITE PLAN APPROVAL

DISTRICT RA2UR USE SED


#BEDROOMS 3

1-24-12
Zoning Administrator

MINIMUM BUILDING SET BACKS

FRONT YARD	35'
REAR YARD	25'
SIDE YARD	10'
CORNER LOT SIDE YARD	20'
MAXIMUM HEIGHT	35'

SAW GRASS COURT (50' R/W)



PROPOSED PLOT PLAN

LOT 24 WALNUT GROVE S/D

ANDERSON CREEK TOWNSHIP - HARNETT COUNTY - NORTH CAROLINA

HOUSE PLAN (CUMBERLAND)

OWNER: EVEN PAR DEVELOPMENT LLC
126 BRANDON DRIVE
LILLINGTON, NC 27546
(919) 422-7065

DEED BOOK 2497, PAGE 479
MAP NO. 2008-737
PARCEL ID: 010525 0062 33
PIN NO 0525-96-3596.000

