

County of Harnett  
Building Inspections Department  
Planning Services

**Certificate of Compliance:** X **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

**Permit Numbers**

Name: GMB Devel.

Building: 12-5008244

Address: 51 Executive Dr

Electrical: IX

Insulation: IX

Plumbing: IX

Mechanical: IX

MFG Home: \_\_\_\_\_

Date: 6-18-12

Building Official: A. Ward Reau

ADDRESS : 51 EXECUTIVE DR SUBDIV: OAKMONT PHASE 1 SECT1  
 CONTRACTOR : GML DEVELOPMENT INC PHONE : (919) 793-5237  
 OWNER : OAK MOUNT DEVELOPERS PHONE :  
 PARCEL : 03-0507- - -0046- -02-  
 APPL NUMBER: 12-50028244 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 02/06/2012 08:24 AM VBROWN ----  
 EXECUTIVE DRIVE, OAKMOUNT SUB DIV #2.  
 27W, LEFT ON DOCS RD, LEFT ON EXECUTIVE  
 WAY.

STRUCTURE: 000 000 55.8X63.9 4BDR 3.5BATH SFD W GAR,CRAWL  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEWTANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/06/12	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002200184
	3/06/12	AP	T/S: 03/06/2012 01:15 PM MREARIC -----
B103 01	3/12/12	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002202155
	3/12/12	DA	T/S: 03/12/2012 03:59 PM MREARIC ----- pier missing projection
B103 02	3/16/12	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002203993
	3/16/12	AP	T/S: 03/16/2012 12:46 PM MREARIC -----
A814 01	3/16/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002204063
	3/20/12	AP	T/S: 03/15/2012 12:18 PM VBROWN ----- 51 executive dr lot 2 lillington 27546----- T/S: 03/20/2012 04:30 PM TWARD -----
B105 01	3/16/12	MR	R*OPEN FLOOR TIME: 17:00 VRU #: 002204071
	3/16/12	AP	T/S: 03/15/2012 12:18 PM VBROWN ----- T/S: 03/16/2012 12:48 PM MREARIC -----
R427 01	4/19/12	MR	FOUR TRADE ROUGH IN >2500 VRU #: 002217292
	4/19/12	AP	T/S: 04/19/2012 12:01 PM MREARIC -----
I129 01	4/23/12	MR	R*INSULATION INSPECTION VRU #: 002218157
	4/23/12	AP	T/S: 04/23/2012 09:19 AM MREARIC -----
H824 01	5/07/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002225209
	5/07/12	AP	T/S: 05/09/2012 10:19 AM SZIMMER ----- T/S: 05/09/2012 10:20 AM SZIMMER -----
R431 01	6/14/12	MR	FOUR TRADE FINAL >2500 VRU #: 002239303
	6/14/12	DA	T/S: 06/14/2012 01:46 PM MREARIC ----- brace deck dining room outlets to be on arc-fault insulation is missing in spots in crawlspace temp power ok'd
R431 02	6/18/12	TI	FOUR TRADE FINAL >2500 VRU #: 002240462

67842 AP-MR

COMMENTS AND NOTES