


**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 3-2-7-10-13-12
 Proposed Facility: 500 Design Flow (.1949): 360 Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 20%	0-16	LS-LON	FR GRANSP					
		10-36	SC-CMAY	FR M ^m S.P.	24-36"	7.5% 4.1			03
2	L 25%	0-8	LON	FR GRANSD					
		8-24	SC-CMAY	FR M ^m S.P.	16-18"	7.5% 4.1			02
3	L 25%	0-10	SLON	FR GRANSP					
		10-40	SC-CMAY	FR M ^m S.P.	12"-16-20"	7.5% 4.1			02
4	L 20%	0-8	SLON	FR GRANSP					
		8-32	SC-CMAY	FR M ^m S.P.	16-18"	7.5% 4.1			02
5	L 20%	0-8	SLON	FR GRANSP					
		8-30	SC-CMAY	FR M ^m S.P.	16-20"	7.5% 4.1			02
6	L 20%	0-10	LON	FR GRANSP					
		10-24	GLYCOLE SOIL	FR MASSIE ADU					
7-8	L 50%	0-20	SL	FR GRANSP					
		20-40	SC-CMAY	FR M ^m S.P.	36"	7.5% 4.1			03

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input checked="" type="checkbox"/>	Other Factors (.1946): Site Classification (.1948): Evaluated By:  Others Present:
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	250	250	
Site LTAR	03	03	