
ADDRESS : 447 JUNO DR SUBDIV: TINGEN POINTE PH 5 33LOTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : THE HARNETT LAND GROUP #143 PHONE : (910) 893-5063
 PARCEL : 03-9576-01- -0088- -47-
 APPL NUMBER: 12-50028441 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/24/2012 12:20 PM DJOHNSON --
 TINGEN POINTE LOT 143
 27 WEST GO PAST WESTERN HARNETT HIGH
 AND MIDDLE SCHOOLS. GO ABOUT ANOTHER 3
 MILES AND THE SUBD IS ON THE LEFT.
 TAKE OMAHA DR THEN RIGHT ON JUNO DR LOT
 ON LEFT
 *****70276477*****

STRUCTURE: 000 000 50X56 3 BR ATT GARAGE CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	8/16/12 8/21/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002266088 447 JUNO DR LOT 143 BROADWAY 27505----- T/S: 08/21/2012 01:02 PM TWARD -----
B101 01	8/16/12 8/16/12	DT AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002266096
B103 01	8/20/12 8/20/12	MR CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 002267706 T/S: 08/20/2012 12:31 PM MREARIC -----
B103 02	8/22/12 8/22/12	MR DA	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002268548 T/S: 08/20/2012 01:30 PM VBROWN ----- T/S: 08/22/2012 01:43 PM MREARIC ----- projection of pier closest to access hole
B103 03	8/23/12 8/23/12	MR CA	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002269678 T/S: 08/23/2012 12:04 PM MREARIC -----
B103 04	8/27/12 8/27/12	FS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002270312 T/S: 08/27/2012 03:08 PM FSPIVEY -----
B105 01	8/27/12 8/27/12	FS AP	R*OPEN FLOOR VRU #: 002270320 T/S: 08/27/2012 03:08 PM FSPIVEY -----
R425 01	9/10/12	TI	FOUR TRADE ROUGH IN VRU #: 002276012

9-10-12 AP-MB

----- COMMENTS AND NOTES -----

ADDRESS : 447 JUNO DR SUBDIV: TINGEN POINTE PH 5 33LOTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : THE HARNETT LAND GROUP #143 PHONE : (910) 893-5063
 PARCEL : 03-9576-01- -0088- -47-
 APPL NUMBER: 12-50028441 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/24/2012 12:20 PM DJOHNSON --
 TINGEN POINTE LOT 143
 27 WEST GO PAST WESTERN HARNETT HIGH
 AND MIDDLE SCHOOLS. GO ABOUT ANOTHER 3
 MILES AND THE SUBD IS ON THE LEFT.
 TAKE OMAHA DR THEN RIGHT ON JUNO DR LOT
 ON LEFT
 *****70276477*****

STRUCTURE: 000 000 50X56 3 BR ATT GARAGE CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	8/16/12 8/21/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002266088 447 JUNO DR LOT 143 BROADWAY 27505----- T/S: 08/21/2012 01:02 PM TWARD -----
B101 01	8/16/12 8/16/12	DT AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002266096
B103 01	8/20/12 8/20/12	MR CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 002267706 T/S: 08/20/2012 12:31 PM MREARIC -----
B103 02	8/22/12 8/22/12	MR DA	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002268548 T/S: 08/20/2012 01:30 PM VBROWN ----- T/S: 08/22/2012 01:43 PM MREARIC ----- projection of pier closest to access hole
B103 03	8/23/12 8/23/12	MR CA	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002269678 T/S: 08/23/2012 12:04 PM MREARIC -----
B103 04	8/27/12 8/27/12	FS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002270312 T/S: 08/27/2012 03:08 PM FSPIVEY -----
B105 01	8/27/12 8/27/12	FS AP	R*OPEN FLOOR VRU #: 002270320 T/S: 08/27/2012 03:08 PM FSPIVEY -----
R425 01	9/10/12 9/10/12	MR AP	FOUR TRADE ROUGH IN VRU #: 002276012 T/S: 09/10/2012 12:57 PM MREARIC -----
I129 01	9/12/12	TI	R*INSULATION INSPECTION VRU #: 002276590

9-12-12 AP:MF

COMMENTS AND NOTES

ADDRESS : 447 JUNO DR
 CONTRACTOR : WYNN CONSTRUCTION, INC.
 OWNER : THE HARNETT LAND GROUP #143
 PARCEL : 03-9576-01- -0088- -47-
 APPL NUMBER: 12-50028441 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/24/2012 12:20 PM DJOHNSON --
 TINGEN POINTE LOT 143
 27 WEST GO PAST WESTERN HARNETT HIGH
 AND MIDDLE SCHOOLS. GO ABOUT ANOTHER 3
 MILES AND THE SUBD IS ON THE LEFT.
 TAKE OMAHA DR THEN RIGHT ON JUNO DR LOT
 ON LEFT
 *****70276477*****

STRUCTURE: 000 000 50X56 3 BR ATT GARAGE CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	8/16/12 8/21/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002266088 447 JUNO DR LOT 143 BROADWAY 27505----- T/S: 08/21/2012 01:02 PM TWARD -----
B101 01	8/16/12 8/16/12	DT AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002266096
B103 01	8/20/12 8/20/12	MR CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 002267706 T/S: 08/20/2012 12:31 PM MREARIC -----
B103 02	8/22/12 8/22/12	MR DA	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002268548 T/S: 08/20/2012 01:30 PM VBROWN ----- T/S: 08/22/2012 01:43 PM MREARIC ----- projection of pier closest to access hole
B103 03	8/23/12 8/23/12	MR CA	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002269678 T/S: 08/23/2012 12:04 PM MREARIC -----
B103 04	8/27/12 8/27/12	FS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002270312 T/S: 08/27/2012 03:08 PM FSPIVEY -----
B105 01	8/27/12 8/27/12	FS AP	R*OPEN FLOOR VRU #: 002270320 T/S: 08/27/2012 03:08 PM FSPIVEY -----
R425 01	9/10/12 9/10/12	MR AP	FOUR TRADE ROUGH IN VRU #: 002276012 T/S: 09/10/2012 12:57 PM MREARIC -----
I129 01	9/12/12 9/12/12	MR AP	R*INSULATION INSPECTION VRU #: 002276590 T/S: 09/12/2012 12:10 PM MREARIC -----
H824 01	10/03/12 10/03/12	BM AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002287209 T/S: 10/04/2012 09:45 AM SSTEWARD ----- T/S: 10/04/2012 09:45 AM SSTEWARD -----
R429 01	10/11/12	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002288876

10-11-12 DAMR

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 10/11/2012

PERMIT # 12-50028441

ADDRESS: 447 juno

1. The access door to the attic must be weather-stripped and insulated to R-10
2. Seal the siding over and around the electric panel

Mike Rearic cell# (910) 984- 4772