

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: Date Evaluated: 7/2/2017
 Address: Design Flow (.1949): Property Size:
 Proposed Facility: Property Recorded:
 Location of Site:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	LS79	0-32	G/LS	VF _h N _h NP					
		32-38	SBK/SC1	FrSSP	104R7/134"				PS.5
		0-24	G/LS	VF _h N _h NP					
		24-31	SBK/SC1	FrSSP	104R7/134"				PS.5
		0-20	G/LS	VF _h N _h NP					
		20-36	SBK/SC1	FrSSP					PS.5

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: B Others Present:
Available Space (.1945)			
System Type(s)	250	100 to 250	
Site LTAR	.5	.5	

1250028441




S12°30'55"E
96.91

S80°42'10"W 153.22

S80°59'06"W 159.11

(144)

(142)



9.98=L N09°00'54"W
2025.00=R 85.99

JUND DRIVE
50' PUBLIC R/W



*Charlie T. Carpenter L-4486
3/1/12*

THIS MAP WAS PREPARED FROM RECORDED DATA, AS NOTED, AND FROM OTHER SOURCES PROVIDED BY THE OWNER. THIS IS A PRELIMINARY SITE PLAN, INTENDED FOR PLANNING USE ONLY AND IN NO WAY REPRESENTS A SURVEY MADE BY THIS COMPANY. THIS MAP IS NOT INTENDED FOR RECORDATION, CONVEYANCES, OR SALES.

Charlie T. Carpenter, P.L.S.
Professional Land Surveyor
1940 Juniper Church Road
Four Oaks, NC 27524
(919) 963-2909
(919) 320-5281

PRELIMINARY SITE PLAN FOR:
WYNN CONSTRUCTION

PIN
PARCEL ID
LOT 143 TINGEN POINTE S/D
PB2012 PG86
2/29/12
1"=40'

JUND DRIVE
BROADWAY, NC 27505