

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: x Occupancy: x

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: Gary Robinson Homes

Building: 12-50028447

Electrical: 11

Address: 141 Tactical Dr.

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: _____

Date: 7-25-12

Building Official: T. Michael Ream

ADDRESS : 141 TACTICAL DR
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER : PARADISE HOMES
 PARCEL : 01-0547- - -0024- -10-
 APPL NUMBER: 12-50028447 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/28/2012 09:20 AM JBROCK ----
 HWY 210 APPROX 14 MILES ON LEFT LOT 7

SUBDIV: GWEN OAKS 63 LOTS
 PHONE : (910) 977-2562
 PHONE :

STRUCTURE: 000 000 33X38.4 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/05/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002212395
	4/05/12	AP	
B103 01	4/12/12	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002214567
	4/12/12	AP	Premise Number: 38133173 T-POLE PASSED
A814 01	4/12/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002214559
	4/13/12	AP	141 tactical dr lot 7 bunnlevel 28323 T/S: 04/13/2012 03:56 PM TWARD
B105 01	4/19/12	JH	R*OPEN FLOOR VRU #: 002217073
	4/19/12	AP	
R425 02	5/18/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002228484
	5/18/12	CA	T/S: 05/17/2012 12:33 PM DJOHNSON PER BILLY
R425 03	5/22/12	DT	FOUR TRADE ROUGH IN VRU #: 002229854
	5/22/12	DA	T/S: 05/22/2012 12:08 PM DETAYLOR Need letter for notched lvls Window within 24 inches of rear door must be tempered by final Okay to side and insulate
R425 04	5/24/12	DT	FOUR TRADE ROUGH IN VRU #: 002231108
	5/24/12	AP	T/S: 05/24/2012 11:51 AM DETAYLOR
I129 01	6/01/12	TI	R*INSULATION INSPECTION VRU #: 002233971
	6/01/12	CA	per billy
I129 02	6/05/12	DT	R*INSULATION INSPECTION VRU #: 002234979
	6/05/12	AP	T/S: 06/05/2012 10:27 AM DETAYLOR
H824 01	6/18/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002241727
	6/19/12	AP	T/S: 06/19/2012 09:11 AM SSTEWARD T/S: 06/19/2012 09:12 AM SSTEWARD
R429 01	7/24/12	DT	FOUR TRADE FINAL VRU #: 002255883
	7/24/12	CA	T/S: 07/24/2012 12:11 PM DETAYLOR Per Billy
R429 02	7/25/12	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002256709
	7-25-12	AP-MR	T/S: 07/24/2012 12:18 PM VBROWN

COMMENTS AND NOTES