

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 3 ~~860000~~ Design Flow (.1949): 360 ~~gpd~~
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 3-7%	0-58	G SL	VFA NS/ND					
		18-34"	SBK SCL	F2 SS/SP	10YR 7/2 @ 32"				PS .3
2		0-14"	G SL	VFA NS/ND					
		14-30"	SBK SCL	F2 SS/SP	10YR 7/2 @ 24"				PS .3
3		0-12"	G SL	VFA NS/ND					
		12-30"	SBK SCL	F2 SS/SP	10YR 7/2 @ 18"				US
4		0-30"	G SL	VFA NS/ND					
		10-30"	SBK SCL	F2 SS/SP	10YR 7/2 @ 24"				PS .3
5		0-14"	G SL	VFA NS/ND					
		14-28"	SBK SCL	F2 SS/SP	10YR 7/2 @ 24"				PS .3

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OS Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	Pump & Treat	LR2	
Site LTAR	3	3	