## HTE# 12-5-2845 Harnett County Department of Public Health

**Improvement** Permit

26910

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: Narks Rd.

SUBDIVISION Coper Forms LOT # 34

NEW REPAIR . EXPANSION Site Improvements required prior to Construction Authorization Issuance: Type of Structure: SFD 48X51 Proposed Wastewater System Type: 25% Reduction System Projected Daily Flow: \_\_\_\_\_\_\_ GPD Basement Yes ₩ No Pump Required: TYes ☐ May\_be required based on final location and elevations of facilities Type of Water Supply: 

Community Public Well Distance from well \_\_\_\_\_\_\_feet Five years Permit valid for: Permit conditions: ☐ No expiration Authorized State Agent: Nymain REH Date: 3/12/2012 SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance ISSUED TO: Wyan Construction

PROPERTY LOCATION: Marks Rd.

SUBDIVISION Cooper Forms

LOT # 74


Facility Type: SPD No Basement Fixtures? Yes No

Type of Wastewater System\*\* 257. Reduction System (Initial) Wastewater Flow: 360 GPD (See note below, if applicable □) 25% Reduction System (Repair)

Ons Number of trenches \_\_\_\_\_\_\_ Installation Requirements/Conditions Septic Tank Size / 00 0 gallons Pump Tank Size \_\_\_\_\_ gallons Maximum Trench Depth of: 24-30 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_ft. TDH vs. \_\_\_\_\_ GPM \_\_\_\_\_ inches below pipe Aggregate Depth: \_\_\_\_\_\_ inches above pipe Conditions: \_\_\_\_\_ inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Sugar Motor an Rotts Construction Authorization Expiration Date: 2/12/24/7

## Harnett County Department of Public Health Site Sketch

	PROPERTY LOCATON: / Carkr Rd.	
ISSUED TO: Wynn Construction	SUBDIVISION Cooper Farms	LOT # <u>_</u> <i>34</i>
		/
Authorized State Agent: Jugan Waring RE141	Date: 3/12/	12012



TAFT Love