

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address:

Proposed Facility: 4 BEDROOM

Location of Site:

Water Supply:

Evaluation Method:  Auger Boring

Type of Wastewater:

Date Evaluated: 5/15/2012

Design Flow (.1949): 460 GPD

Property Recorded:

Public  Individual  Well

Pit  Cut

Industrial Process

Property Size:

Spring

Other

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-15	G S	VFR NS/HP					
		15-29	SBK C	F1 S/P	10YR 7/2 e 25"				PS.3
2		0-16	G S	VFR NS/HP					
		16-20	SBK C	F1 S/P	10YR 7/2 e 26"				PS.3
3		0-16	G S	VFR NS/HP					
		16-30	SBK SCL	F2 S/P	10YR 7/2 e 26"				PS.3
4		0-15	G S	VFR NS/HP					
		15-30	SBK SCL	F1 S/P	10YR 7/2 e 27"				
5		0-22"	G S	VFR NS/HP					
		22-36"	SBK SCL	F2 S/P	10YR 7/2 e 33"				PS.35
C		0-18	G S	VFR NS/HP					
		18-34	SBK SCL	F2 S/P	10YR 7/2 e 34"				PS.35

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: gm Others Present: OT Mr. + Mrs. Myers
Available Space (.1945)			
System Type(s)	25"	4 + Grade 3/2	
Site LTAR	35"	25.3	