

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: *[Signature]*
 Address: Date Evaluated: 3-27-28-29-12
 Proposed Facility: *SFD* Design Flow (.1949): 480
 Location of Site: Property Recorded: Property Size:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L-5%	0-26	SL	FR GR NBNP					
		26-48	SL	FR GR NBNP	40" 2.5" 2	Pr		2	4
2	L-4%	0-24	SL	FR GR NBNP					
		24-42	SL	FR GR NBNP	42" 2.5" 2	Pr		2	4
3	L	0-24	SL	FR GR NBNP					
		24-40	SL-CL	FR GR NBNP	36"	Pr		Pr	4
4	L	0-18	SL	FR GR NBNP					
		18-36	SL-CL	FR GR NBNP	30"	Pr		Pr	35
5	L	0-24	SL	FR GR NBNP					
		24-40	SL-CL	FR GR NBNP	36"	Pr		Pr	4
6	L	0-30	SL	FR GR NBNP					
		30-40	SL-CL	FR GR NBNP	36"	Pr		Pr	4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>92</i> Others Present:
Available Space (.1945)	/	/	
System Type(s)	<i>250</i>	<i>22</i>	
Site LTAR	<i>14</i>	<i>35</i>	