

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:

Address:

Proposed Facility: 4 bedroom

Location of Site:

Water Supply:

Evaluation Method: Auger Boring

Type of Wastewater:

Date Evaluated:

Design Flow (.1949): 480 gpd

Property Recorded:

Public Individual Well

Pit Cut

Industrial Process

Property Size:

Spring Other

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-48	SBK SCL	FR SS/SP					PS .45
2		0-39	SBK SCL	FR SS/SP	10727/20 32"				PS 425
3		0-34	SBK SCL	FR SS/SP					PS .45
		34-48	G S	VF2 NS/MP					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: -
Available Space (.1945)			
System Type(s)	25" x 10" R57		
Site LTAR	.425	.225	