

ADDRESS : 479 HORNE LN SUBDIV: DOUGLAS L HORNE
 TENANT, NBR: PICKED UP PLANS CUST
 CONTRACTOR : HORNADAY HOMES, LLC PHONE : (910) 483-9715
 OWNER . . . : TANNER CARL W JR PHONE :
 PARCEL . . . : 12-0556- - -0100- -06-
 APPL NUMBER: 12-50028609 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 03/26/2012 10:23 AM VBROWN ----
 479 HORNE LANE
 TAKE 401 TO MCLEAN CHAPEL RD, RUNS TO
 WIRE RD, TURN LEFT ON WALKER, 1/4
 ITURN RIGHT (HORNE LANE-DIRT RD), LAST
 LOT ON LEFT.

STRUCTURE: 000 000 63.8X36 3BDR 2.5BATH SFD GAR, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : EXISTING WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS	VRU #:
B101 01	5/09/12	JH	R*BLDG FOOTING / TEMP SVC POLE	002224907
	5/09/12	AP		
B103 01	5/16/12	JH	R*BLDG FOUND & TEMP SVC POLE	002227334
	5/16/12	AP		
A814 01	5/17/12	TW	ADDRESS CONFIRMATION, TIME: 17:00	002227536
	5/17/12	AP	479 horne ln linden # on home and by drive T/S: 05/17/2012 01:09 PM TWARD	28356
B105 01	5/17/12	JH	R*OPEN FLOOR TIME: 17:00	002227544
	5/17/12	AP		
R327 01	6/28/12	DT	THREE TRADE ROUGH IN >2500	002245001
	6/28/12	AP	T/S: 06/28/2012 11:00 AM DETAYLOR	
I129 01	7/06/12	JH	R*INSULATION INSPECTION TIME: 17:00	002248276
	7/06/12	AP	T/S: 07/05/2012 08:42 AM DJOHNSON	
H824 01	9/06/12	OT	✓ENVR. OPERATIONS PERMIT TIME: 17:00	002276145
	9/06/12	AP	T/S: 09/07/2012 10:53 AM SSTEWARD T/S: 09/07/2012 10:53 AM SSTEWARD	
R431 01	9/11/12	TI	FOUR TRADE FINAL >2500 TIME: 17:00	002277218
	9-11-12	Op JH	T/S: 09/11/2012 07:38 AM DJOHNSON	

COMMENTS AND NOTES

ADDRESS : 479 HORNE LN SUBDIV: DOUGLAS L HORNE
TENANT, NBR: PICKED UP PLANS CUST
CONTRACTOR : HORNADAY HOMES, LLC PHONE : (910) 483-9715
OWNER . . . : TANNER CARL W JR PHONE :
PARCEL . . . : 12-0556- - -0100- -06-
APPL NUMBER: 12-50028609 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/26/2012 10:23 AM VBROWN ----
479 HORNE LANE
TAKE 401 TO MCLEAN CHAPEL RD, RUNS TO
WIRE RD, TURN LEFT ON WALKER, 1/4
ITURN RIGHT (HORNE LANE-DIRT RD), LAST
LOT ON LEFT.

STRUCTURE: 000 000 63.8X36 3BDR 2.5BATH SFD GAR, CRAWL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : EXISTING
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/09/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002224907
	5/09/12	AP	
B103 01	5/16/12	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002227334
	5/16/12	AP	
A814 01	5/17/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002227536
	5/17/12	AP	479 horne ln linden 28356----- # on home and by drive T/S: 05/17/2012 01:09 PM TWARD
B105 01	5/17/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002227544
	5/17/12	AP	
R327 01	6/28/12	DT	THREE TRADE ROUGH IN >2500 VRU #: 002245001
	6/28/12	AP	T/S: 06/28/2012 11:00 AM DETAYLOR
I129 01	7/06/12	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002248276
	7/06/12	AP	T/S: 07/05/2012 08:42 AM DJOHNSON
H824 01	9/06/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002276145
	9/06/12	AP	T/S: 09/07/2012 10:53 AM SSTEWARD
			T/S: 09/07/2012 10:53 AM SSTEWARD
R431 01	9/11/12	JH	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002277218
	9/11/12	DP	T/S: 09/11/2012 07:38 AM DJOHNSON
			1) Insulate trap & water lines for sink in garage 2) Garage door needs to be installed for final inspection. 3) Energy efficiency certificate needs to be filled out compltly per code. 4) Label length of dryer duct within 6' of dryer connection. 5) NO water on house. 6) Do not support garbage disposol wires on ddrain lines under sink. 7) Need pickets on back screen in porch per code it is over 30"H & 36"out. 8) Caulk all plumbing fixtures per code. 9) Receptacle for master tub needs to be mounted @ door facing out. 10) Need ladder for attic access & missing access door with insulation & weather stripping. 11) Missing dead bolt on front door. 12) Missing house numbers per code. 13) Fill in all ditches around house & need 6" in 10' grade from house. 14) All outside receptacles are not attached to boxes on

CONTINUED ONTO NEXT PAGE

ADDRESS : 479 HORNE LN SUBDIV: DOUGLAS L HORNE
 TENANT, NBR: PICKED UP PLANS CUST
 CONTRACTOR : HORNADAY HOMES, LLC PHONE : (910) 483-9715
 OWNER : TANNER CARL W JR PHONE :
 PARCEL : 12-0556- - -0100- -06-
 APPL NUMBER: 12-50028609 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
			ends.15)Label AHU in crawl.16)Missing crawl door.17)Need 6 mil poly in crawl lapped 12" & pinned in place.18)Pad for condensing units needs to sit on grade.19)Sewer line needs to be connected per code & cover up @ final inspection.20)Pad to left of house was questioned about permits home owner said it was turned down 5 years ago & he was not doing anything with it.

R429 01 9/28/12 TI FOUR TRADE FINAL TIME: 17:00 VRU #: 002284412

9-28-12 Op JV

4 710/5 18

 COMMENTS AND NOTES
