

ADDRESS : 104 PARKVIEW LN SUBDIV: ROSEMONT PH2 19LOTS  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER : CAVINESS LAND DEV PHONE : (910) 339-6332  
 PARCEL : 01-0536-07- -0028- -02-  
 APPL NUMBER: 12-50028636 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 03/28/2012 01:40 PM JBROCK ----  
 87 S MAKE A LEFT ONTO NURSERY RD AND  
 THEN CONT TO THE LEFT ON NURSERY RD  
 MAKE INTO ROSEMONT S/D 6TH LOT ON RIGHT  
 LOT 9

8.20.12

STRUCTURE: 000 000 40X40 4BDR MONO W/ GARAGE & COV PORCH  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/11/12	MR	R*PLUMB UNDER SLAB VRU #: 002225835
	5/11/12	AP	T/S: 05/11/2012 12:44 PM MREARIC -----
B114 01	5/16/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002227056
	5/16/12	DA	1)Insulation is required on perimeter wallsthat would include garage/house wall.2)Remove loose dirt in footing @ corners of garage.3)Remove stakes from lug footings on garage walls
B114 02	5/17/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002227999
	5/17/12	AP	T/S: 05/17/2012 08:12 AM VBROWN -----
R425 01	6/08/12	MR	FOUR TRADE ROUGH IN VRU #: 002237225
	6/08/12	DA	T/S: 06/08/2012 12:20 PM MREARIC ----- re-caulk all plmb penetrations provide nail guards on gray wire by panel no 3" pancakes
R425 02	6/12/12	DT	FOUR TRADE ROUGH IN VRU #: 002238368
	6/12/12	AP	T/S: 06/12/2012 11:53 AM DETAYLOR -----
I129 01	6/14/12	MR	R*INSULATION INSPECTION VRU #: 002239081
	6/15/12	AP	T/S: 06/15/2012 12:42 PM MREARIC -----
H824 01	7/05/12	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002248912
	7/05/12	AP	T/S: 07/06/2012 10:31 AM SSTEWARD ----- T/S: 07/06/2012 10:31 AM SSTEWARD -----
A814 01	8/09/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002261331
	8/10/12	AP	104 Parkivew Ln lot 9 Lillington 27546----- T/S: 08/10/2012 02:42 PM TWARD -----
R429 01	8/14/12	TI	FOUR TRADE FINAL VRU #: 002264800

8/14/12 DA DT

COMMENTS AND NOTES

-----

ADDRESS : 104 PARKVIEW LN SUBDIV: ROSEMONT PH2 19LOTS  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
 OWNER : CAVINESS LAND DEV PHONE : (910) 339-6332  
 PARCEL : 01-0536-07- -0028- -02-  
 APPL NUMBER: 12-50028636 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 03/28/2012 01:40 PM JEROCK ----  
 87 S MAKE A LEFT ONTO NURSERY RD AND  
 THEN CONT TO THE LEFT ON NURSERY RD  
 MAKE INTO ROSEMONT S/D 6TH LOT ON RIGHT  
 LOT 9

-----

STRUCTURE: 000 000 40X40 4BDR MONO-W/ GARAGE & COV PORCH  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/11/12 <u>5-11-12</u>	TI <u>AP-MR</u>	R*PLUMB UNDER SLAB VRU #: 002225835

----- COMMENTS AND NOTES -----

PREPARED 5/15/12, 14:00:26  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 24  
DATE 5/16/12

ADDRESS : 104 PARKVIEW LN  
CONTRACTOR : CAVINESS LAND DEVELOPMENT  
OWNER : CAVINESS LAND DEV  
PARCEL : 01-0536-07- -0028- -02-  
APPL NUMBER: 12-50028636 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 03/28/2012 01:40 PM JBROCK ----  
87 S MAKE A LEFT ONTO NURSERY RD AND  
THEN CONT TO THE LEFT ON NURSERY RD  
MAKE INTO ROSEMONT S/D 6TH LOT ON RIGHT  
LOT 9

SUBDIV: ROSEMONT PH2 19LOTS  
PHONE : (919) 481-0503  
PHONE : (910) 339-6332

STRUCTURE: 000 000 40X40 4BDR MONO W/ GARAGE & COV PORCH

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 4000000.00

SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/11/12	MR	R*PLUMB UNDER SLAB VRU #: 002225835
	5/11/12	AP	T/S: 05/11/2012 12:44 PM MREARIC
B114 01	5/16/12	TI	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002227056
	<u>5-16-12</u>	<u>DA-JH</u>	

COMMENTS AND NOTES

PREPARED 5/17/12, 8:14:32  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 1  
DATE 5/17/12

-----  
ADDRESS . . : 104 PARKVIEW LN  
CONTRACTOR : CAVINESS LAND DEVELOPMENT  
OWNER . . . : CAVINESS LAND DEV  
PARCEL . . . : 01-0536-07- -0028- -02-  
APPL NUMBER: 12-50028636 CP NEW RESIDENTIAL (SFD)  
-----

DIRECTIONS : T/S: 03/28/2012 01:40 PM JBROCK -----  
87 S MAKE A LEFT ONTO NURSERY RD AND  
THEN CONT TO THE LEFT ON NURSERY RD  
MAKE INTO ROSEMONT S/D 6TH LOT ON RIGHT  
LOT 9  
-----

STRUCTURE: 000 000 40X40 4BDR MONO W/ GARAGE & COV PORCH  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 4000000.00  
SEPTIC - EXISTING? . . . . : NEW  
PROPOSED USE . . . . . : SFD  
WATER SUPPLY . . . . . : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/11/12	MR	R*PLUMB UNDER SLAB VRU #: 002225835
	5/11/12	AP	T/S: 05/11/2012 12:44 PM MREARIC -----
B114 01	5/16/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002227056
	5/16/12	DA	Insulation is required on perimeter wall that would include garage/house wall. Remove loose dirt in footing @ corners of garage. Remove stakes from lug footings on garage walls
B114 02	5/17/12	TI	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002227999
	5-17-12	APJH	T/S: 05/17/2012 08:12 AM VBROWN -----

----- COMMENTS AND NOTES -----

PREPARED: 6/07/12, 13:59:48  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 29  
DATE 6/08/12

ADDRESS : 104 PARKVIEW LN  
CONTRACTOR : CAVINESS LAND DEVELOPMENT  
OWNER : CAVINESS LAND DEV  
PARCEL : 01-0536-07- -0028- -02-  
APPL NUMBER: 12-50028636 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 03/28/2012 01:40 PM JBROCK -----  
87 S MAKE A LEFT ONTO NURSERY RD AND  
THEN CONT TO THE LEFT ON NURSERY RD  
MAKE INTO ROSEMONT S/D 6TH LOT ON RIGHT  
LOT 9

SUBDIV: ROSEMONT PH2 19LOTS  
PHONE : (919) 481-0503  
PHONE : (910) 339-6332

STRUCTURE: 000 000 40X40 4BDR MONO W/ GARAGE & COV PORCH

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 4000000.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/11/12	MR	R*PLUMB UNDER SLAB VRU #: 002225835
	5/11/12	AP	T/S: 05/11/2012 12:44 PM MREARIC -----
B114 01	5/16/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002227056
	5/16/12	DA	1)Insulation is required on perimeter wallsthat would include garage/house wall.2)Remove loose dirt in footing @ corners of garage.3)Remove stakes from lug footings on garage walls
B114 02	5/17/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002227999
	5/17/12	AP	T/S: 05/17/2012 08:12 AM VBROWN -----
R425 01	6/08/12	TI	FOUR TRADE ROUGH IN VRU #: 002237225
	<u>6-8-12</u>	<u>DA-MR</u>	

COMMENTS AND NOTES

OK to Side

# **HARNETT COUNTY**

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 06/08/2012

PERMIT # 12-50028636

ADDRESS: 104 parkview

1. Re-caulk all plumbing penetrations through floors and ceilings
2. Provide nail guards at gray wire by panel where less than 1-1/4"
3. No 3" pancake boxes are permitted
4. Provide correct sealing at stair junction with garage wall

Mike Rearic cell# (910) 984- 4772

ADDRESS : 104 PARKVIEW LN  
 CONTRACTOR : CAVINESS LAND DEVELOPMENT  
 OWNER : CAVINESS LAND DEV  
 PARCEL : 01-0536-07- -0028- -02-  
 APPL NUMBER: 12-50028636 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 03/28/2012 01:40 PM JBROCK ----  
 87 S MAKE A LEFT ONTO NURSERY RD AND  
 THEN CONT TO THE LEFT ON NURSERY RD  
 MAKE INTO ROSEMONT S/D 6TH LOT ON RIGHT  
 LOT 9

SUBDIV: ROSEMONT PH2 19LOTS  
 PHONE : (919) 481-0503  
 PHONE : (910) 339-6332

82012

STRUCTURE: 000 000 40X40 4BDR MONO W/ GARAGE & COV PORCH

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4000000.00  
 SEPTIC - EXISTING? : NEW  
 PROPOSED USE : SFD  
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/11/12	MR	R*PLUMB UNDER SLAB VRU #: 002225835
	5/11/12	AP	T/S: 05/11/2012 12:44 PM MREARIC -----
B114 01	5/16/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002227056
	5/16/12	DA	1)Insulation is required on perimeter wallsthat would include garage/house wall.2)Remove loose dirt in footing @ corners of garage.3)Remove stakes from lug footings on garage walls
B114 02	5/17/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002227999
	5/17/12	AP	T/S: 05/17/2012 08:12 AM VBROWN -----
R425 01	6/08/12	MR	FOUR TRADE ROUGH IN VRU #: 002237225
	6/08/12	DA	T/S: 06/08/2012 12:20 PM MREARIC ----- re-caulk all plmb penetrations provide nail guards on gray wire by panel no 3" pancakes
R425 02	6/12/12	TI	FOUR TRADE ROUGH IN VRU #: 002238368
	6/12/12	AP	

COMMENTS AND NOTES

-----  
ADDRESS . . : 104 PARKVIEW LN SUBDIV: ROSEMONT PH2 19LOTS  
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503  
OWNER . . . : CAVINESS LAND DEV PHONE : (910) 339-6332  
PARCEL . . . : 01-0536-07- -0028- -02-  
APPL NUMBER: 12-50028636 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 03/28/2012 01:40 PM JBROCK -----  
87 S MAKE A LEFT ONTO NURSERY RD AND  
THEN CONT TO THE LEFT ON NURSERY RD  
MAKE INTO ROSEMONT S/D 6TH LOT ON RIGHT  
LOT 9  
-----

STRUCTURE: 000 000 40X40 4BDR MONO W/ GARAGE & COV PORCH  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 4000000.00 PROPOSED USE . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/11/12	MR	R*PLUMB UNDER SLAB VRU #: 002225835
	5/11/12	AP	T/S: 05/11/2012 12:44 PM MREARIC -----
B114 01	5/16/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002227056
	5/16/12	DA	1)Insulation is required on perimeter wallsthat would include garage/house wall.2)Remove loose dirt in footing @ corners of garage.3)Remove stakes from lug footings on garage walls -----
B114 02	5/17/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002227999
	5/17/12	AP	T/S: 05/17/2012 08:12 AM VBROWN -----
R425 01	6/08/12	MR	FOUR TRADE ROUGH IN VRU #: 002237225
	6/08/12	DA	T/S: 06/08/2012 12:20 PM MREARIC ----- re-caulk all plmb penetrations provide nail guards on gray wire by panel no 3" pancakes
R425 02	6/12/12	DT	FOUR TRADE ROUGH IN VRU #: 002238368
	6/12/12	AP	T/S: 06/12/2012 11:53 AM DETAYLOR -----
I129 01	6/14/12	TI	R*INSULATION INSPECTION VRU #: 002239081

6-15-12 AP-MR

----- COMMENTS AND NOTES -----

garage ceiling