

PREPARED 5/10/12, 13:58:51
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 25
DATE 5/11/12

ADDRESS . . : 89 PARKVIEW LN
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER . . . : CAVINESS LAND DEV
PARCEL . . . : 01-0536-07- -0028- -11-
APPL NUMBER: 12-50028638 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/28/2012 01:40 PM JBROCK ----
87 S MAKE A LEFT ONTO NURSERY RD AND
THEN CONT TO THE LEFT ON NURSERY RD
MAKE INTO ROSEMONT S/D 6TH LOT ON RIGHT
LOT 18

STRUCTURE: 000 000 40.5X45.75 3BDR SLAB W/ GARAGE & COV POR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSP 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/11/12 <i>S-11-12</i>	TI <i>APMR</i>	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002225852 T/S: 05/10/2012 01:05 PM DJOHNSON -----

COMMENTS AND NOTES

ADDRESS . . . : 89 PARKVIEW LN-
 CONTRACTOR : CAVINESS LAND DEVELOPMENT
 OWNER . . . : CAVINESS LAND DEV
 PARCEL . . . : 01-0536-07- -0028- -11-
 APPL NUMBER: 12-50028638 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/28/2012 01:40 PM JBROCK -----
 87 S MAKE A LEFT ONTO NURSERY RD AND
 THEN CONT TO THE LEFT ON NURSERY RD
 MAKE INTO ROSEMONT S/D 6TH LOT ON RIGHT
 LOT 18

SUBDIV: ROSEMONT PH2 19LOTS
 PHONE : (919) 481-0503
 PHONE : (910) 339-6332

STRUCTURE: 000 000 40.5X45.75 3BDR SLAB W/ GARAGE & COV POR
 FLOOD ZONE . . . : FLOOD ZONE X
 # BEDROOMS . . . : 3000000.00
 SEPTIC - EXISTING? . . . : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/11/12	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002225852
	5/11/12	AP	T/S: 05/10/2012 01:05 PM DJOHNSON -----
			T/S: 05/11/2012 12:49 PM MREARIC -----
B114 01	5/16/12	TI	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002227064

5-16-12 *DAV*

COMMENTS AND NOTES

ADDRESS' . . : 89 PARKVIEW LN SUBDIV: ROSEMONT PH2 19LOTS
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . . : CAVINESS LAND DEV PHONE : (910) 339-6332
PARCEL . . . : 01-0536-07- -0028- -11-
APPL NUMBER: 12-50028638 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 03/28/2012 01:40 PM JBROCK -----
87 S MAKE A LEFT ONTO NURSERY RD AND
THEN CONT TO THE LEFT ON NURSERY RD
MAKE INTO ROSEMONT S/D 6TH LOT ON RIGHT
LOT 18

STRUCTURE: 000 000 40.5X45.75 3BDR SLAB W/ GARAGE & COV POR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/11/12 5/11/12	MR AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002225852 T/S: 05/10/2012 01:05 PM DJOHNSON ----- T/S: 05/11/2012 12:49 PM MREARIC -----
B114 01	5/16/12 5/16/12	JH DA	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002227064 1) Insulation is required on perimeter walls & that would include garage/house wall. 2) Remove loose dirt from footing.
B114 02	5/17/12 <i>5-17-12</i>	TI <i>AP JH</i>	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002227981 T/S: 05/17/2012 08:13 AM VBROWN -----

----- COMMENTS AND NOTES -----

ADDRESS : 89 PARKVIEW LN SUBDIV: ROSEMONT PH2 19LOTS
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER : CAVINESS LAND DEV PHONE : (910) 339-6332
PARCEL : 01-0536-07- -0028- -11-
APPL NUMBER: 12-50028638 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/28/2012 01:40 PM JEROCK ----
87 S MAKE A LEFT ONTO NURSERY RD AND
THEN CONT TO THE LEFT ON NURSERY RD
MAKE INTO ROSEMONT S/D 6TH LOT ON RIGHT
LOT 18

STRUCTURE: 000 000 40.5X45.75 3BDR SLAB W/ GARAGE & COV POR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/11/12	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002225852
	5/11/12	AP	T/S: 05/10/2012 01:05 PM DJOHNSON ----- T/S: 05/11/2012 12:49 PM MREARIC -----
B114 01	5/16/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002227064
	5/16/12	DA	1)Insulation is required on perimeter walls & that would include garage/house wall.2)Remove loose dirt from footing.
B114 02	5/17/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002227981
	5/17/12	AP	T/S: 05/17/2012 08:13 AM VBROWN -----
R425 01	6/14/12	TI	FOUR TRADE ROUGH IN VRU #: 002239072

6-14-12 DA-MR

----- COMMENTS AND NOTES -----

D Shim under VL-1, VL-1a
Trusses

ADDRESS : 89 PARKVIEW LN
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : CAVINESS LAND DEV
PARCEL : 01-0536-07- -0028- -11-
APPL NUMBER: 12-50028638 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/28/2012 01:40 PM JBROCK ----
87 S MAKE A LEFT ONTO NURSERY RD AND
THEN CONT TO THE LEFT ON NURSERY RD
MAKE INTO ROSEMONT S/D 6TH LOT ON RIGHT
LOT 18

SUBDIV: ROSEMONT PH2 19LOTS
PHONE : (919) 481-0503
PHONE : (910) 339-6332

8.15.12

STRUCTURE: 000 000 40.5X45.75 3BDR SLAB W/ GARAGE & COV POR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/11/12	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002225852
	5/11/12	AP	T/S: 05/10/2012 01:05 PM DJOHNSON ----- T/S: 05/11/2012 12:49 PM MREARIC -----
B114 01	5/16/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002227064
	5/16/12	DA	1)Insulation is required on perimeter walls & that would include garage/house wall.2)Remove loose dirt from footing.
B114 02	5/17/12	JH	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002227981
	5/17/12	AP	T/S: 05/17/2012 08:13 AM VBROWN -----
R425 01	6/14/12	MR	FOUR TRADE ROUGH IN VRU #: 002239072
	6/14/12	DA	T/S: 06/14/2012 03:30 PM MREARIC ----- shim under trusses vl-1, vl-1a ok to side and insul.
I129 01	6/18/12	TI	R*INSULATION INSPECTION VRU #: 002240658
	<u>6-19-12</u>	<u>AP-MR</u>	
R425 02	6/18/12	TI	FOUR TRADE ROUGH IN VRU #: 002240630
	<u>6-18-12</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

hold till tomorrow
ins. in Garage ceiling