

Improvement Permit

26843

South River Homes
 A building permit cannot be issued with only an Improvement Permit
 PROPERTY LOCATION: 821709 Hodges Chapel CH RD
 ISSUED TO: WARREN Bishop SUBDIVISION: CROWNVIEW LOT # 8
 NEW REPAIR EXPANSION
 Type of Structure: SFD Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% REDUCED SYSTEM
 Projected Daily Flow: 480 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: James E. Marklar Date: 10-26-12 5-3-12 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. *South River Homes*

ISSUED TO: WARREN Bishop PROPERTY LOCATION: 821709 Hodges Chapel CH RD
 SUBDIVISION: CROWNVIEW LOT # 8
 Facility Type: SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% REDUCED SYSTEM (Initial) Wastewater Flow: 360 480 GPD
 (See note below, if applicable MANUFACTURED 25% REDUCED (Repair))
Installation Requirements/Conditions
 Septic Tank Size 1200 gallons Exact length of each trench 120 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size 1600 gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 24" max inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 Soil Cover: 6 inches
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
 Conditions: _____ 2 inches above pipe
12 inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

***If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Marklar Date: 10-26-12
5-3-12
 Construction Authorization Expiration Date: 5-3-17 10-26-17

HTE# 12-5-28764R

Permit # 26843

Harnett County Department of Public Health Site Sketch

South River Home LLC

ISSUED TO: WARREN BISHOP

PROPERTY LOCATION: 521709 Hodges Chapel Ct RD
SUBDIVISION CROWNVIEW LOT # 8

Authorized State Agent:

James E. Markant REHS

Date: 10-26-12

