

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Permit Numbers

Name: BRC Homes, Inc

Building: _____

Address: 101 Pointer Dr

Electrical: _____

Angier, NC 27501

Insulation: _____

Plumbing: _____

Mechanical: 1250028073

MFG Home: _____

Date: 9/6/12

Building Official: _____

D. E. J. C.

ADDRESS : 101 POINTER DR SUBDIV: QUAIL GLEN PH1 32LOTS
 CONTRACTOR : BRC HOMES, INC. PHONE : (919) 422-0355
 OWNER : EMPIRE INVESTMENT GROUP LLC PHONE : (918) 868-5150
 PARCEL : 11-0662- - -0022- -24-
 APPL NUMBER: 12-50028823 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 04/30/2012 08:02 AM JBROCK ----
 210 HWY N LEFT HARNETT CENTRAL RD LEFT
 ON ENGLISH SPRINGER DR RIGHT POINTER DR
 LOT ON LEFT LOT 21

STRUCTURE: 000 000 47X48 4BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/22/12	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002229516
	5/22/12	AP	T/S: 05/22/2012 02:53 PM DETAYLOR -----
A814 01	5/31/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002233153
	5/31/12	AP	✓ 101 pointer dr lot 21 angier 27501 ----- T/S: 05/31/2012 08:10 AM TWARD -----
B103 01	5/31/12	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002233146
	5/31/12	AP	T/S: May 31, 2012 02:17 PM BSUTTON -----
B105 01	6/04/12	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 002234607
	6/04/12	AP	Cut back or flash drop girders at exterior masonry. Check at roughin
R425 01	7/03/12	BS	FOUR TRADE ROUGH IN VRU #: 002247036
	7/03/12	AP	Cover foam insulation at fireplace header. Brace rafter support wall\
I129 01	7/06/12	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002248565
	7/06/12	AP	T/S: July 06, 2012 12:19 PM BSUTTON -----
H824 01	8/02/12	IM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002261139
	8/02/12	AP	T/S: 08/03/2012 10:02 AM SSTEWARD ----- T/S: 08/03/2012 10:03 AM SSTEWARD -----
R431 01	9/06/12	TI	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 002275071

9/6/12 *AP DT*

COMMENTS AND NOTES