

ADDRESS : 41 HUNTERS POINT CT
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : SHC HOLDINGS INC
PARCEL : 07-0691- - -0023- -02-
APPL NUMBER: 12-50028834 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 05/01/2012 10:28 AM VBROWN ----
41 HUNTERS POINT COURT, HUNTERS POINT
SUB DIV #2. 210N TOWARDS ANGIER, RIGHT
ON 55E TOWARDS COATS LEFT ON SILAS
HAYES TAKE 2ND ENT HUNTERS POINT ON
RIGHT.

SUBDIV: HUNTERS POINT 45 LOTS
PHONE : (919) 639-2073
PHONE :

66847385

STRUCTURE: 000 000 54X42 3BDR 2BATH SFD W GAR DECK CRAWL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/25/12	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002243103
	6/25/12	AP	T/S: 06/22/2012 08:51 AM DJOHNSON ----- T/S: June 25, 2012 12:28 PM BSUTTON -----
A814 01	6/26/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002243715
	6/26/12	AP	S: 06/25/2012 11:46 AM DJOHNSON ----- 41 HUNTERS POINT CT LOT 2 ANGIER 27501 T/S: 06/26/2012 10:26 AM TWARD -----
B103 01	7/03/12	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002247468
	7/03/12	AP	T/S: 07/02/2012 03:22 PM VBROWN ----- T/S: July 03, 2012 10:50 AM BSUTTON -----
B105 01	7/24/12	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 002255750
	7/24/12	AP	T/S: 07/23/2012 10:44 AM VBROWN ----- T/S: July 24, 2012 09:08 AM BSUTTON -----
R425 01	8/13/12	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002263465
	8/13/12	DA	T/S: 08/09/2012 09:40 AM VBROWN ----- T/S: 08/13/2012 09:48 AM KSLATTUM ----- 1. Need tempered glass next to rear door. 2. Sleeve drain thru foundation. 3. Remove all vegetation from foundation. 4. Braced wall line B not blocked for nailing sheet rock. ok to side and insulate
I129 01	8/27/12	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002269975
	8/27/12	DA	T/S: 08/24/2012 08:29 AM VBROWN ----- T/S: 08/27/2012 09:29 AM KSLATTUM ----- Cantilever in garage not insulated.
R425 02	8/27/12	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002269983
	8/27/12	DP	T/S: 08/24/2012 08:29 AM VBROWN ----- T/S: 08/27/2012 09:30 AM KSLATTUM ----- Drain thru foundation not sleeved
			\$50 re-inspection fee
I129 02	8/28/12	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002271484
	8/28/12	AP	T/S: 08/28/2012 11:50 AM DETAYLOR -----
R425 03	8/28/12	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002271492
	8/28/12	AP	T/S: 08/28/2012 11:50 AM DETAYLOR -----
H824 01	9/25/12	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002286334
	9/25/12	AP	T/S: 10/02/2012 03:50 PM SSTEWARD -----

PREPARED 10/05/12, 14:06:28
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 8
DATE 10/08/12

ADDRESS : 41 HUNTERS POINT CT
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : SHC HOLDINGS INC
PARCEL : 07-0691- - -0023- -02-
APPL NUMBER: 12-50028834 CP NEW RESIDENTIAL (SFD)

SUBDIV: HUNTERS POINT 45 LOTS
PHONE : (919) 639-2073
PHONE :

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

R429 01 10/08/12 TI T/S: 10/02/2012 03:51 PM SSTEWARD -----
10-8-12 DAB FOUR TRADE FINAL TIME: 17:00 VRU #: 002287985

----- COMMENTS AND NOTES -----