HTE# 12-5-28854

Harnett County Department of Public Health

Improvement Permit

27051

A building permit cannot be issued with only an Improvement Permit ISSUED TO: BILL CLASSE HOMES SUBDIVISION PASSONS POINT REPAIR □ , EXPANSION □ Site Improvements required prior to Construction Authorization Issuance: Type of Structure: SFD (45×50) Proposed Wastewater System Type: CONTENTIONAL Projected Daily Flow: 360 GPD Number of bedrooms: 3 Number of Occupants: 6 max Basement TYes Pump Required: □Yes No 🗆 May be required based on final location and elevations of facilities Type of Water Supply:

Community

Public

Well Distance from well

O feet Permit valid for: Five years Permit conditions: ☐ No expiration Authorized State Agent:: Date: SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the Issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: BYLL CLARK HOMES PROPERTY LOCATION: TINGEN BO Facility Type: SED (45×50)

New | Expansion | Repair

Basement? | Yes | No Basement Fixtures? | Yes | No

Type of Wastewater System** | CONSONEL | (Initial) Wastewater Flow: 360 | GPD (See note below, if applicable ENVENTIONAL (Repair) **Installation Requirements/Conditions** Number of trenches Exact length of each trench \(\frac{\bar{B}}{C} \) feet Trench Spacing: Septic Tank Size 1000 gallons Pump Tank Size gallons Soil Cover: 12-24 Trenches shall be installed on contour at a Maximum Trench Depth of: 25-36 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: _____ft. TDH vs. _____ GPM ____ inches below pipe inches above pipe inches total Aggregate Depth: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: _ Construction Authorization Expiration Date:

me# 100071	HTE#	12-2-	268	54	
------------	------	-------	-----	----	--

Permit # <u>2705)</u>

Harnett County Department of Public Health Site Sketch

Authorized State Agent:

PROPERTY LOCATON: 11 M 66, RD

SUBDIVISION PATTONS POINT LOT # 4)

Date: 5 14 12

