

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: Israel Lucas Construction, Inc.

Building: 12-50028874

Address: 45 Eisenhower Dr. Ct

Electrical: "

Insulation: "

Plumbing: "

Mechanical: "

MFG Home: "

Date: 4-19-13

Building Official: T. Michael Reavis

ADDRESS : 45 EISENHOWER CT SUBDIV: PATTONS POINT
 CONTRACTOR : ISRAEL LUCAS CONSTRUCTION INC PHONE : (919) 770-0902
 OWNER : ISRAEL LUCAS CONST INC PHONE : (919) 770-0902
 PARCEL : 03-9597- - -0039- -63-
 APPL NUMBER: 12-50028874 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 05/03/2012 11:09 AM JBROCK ----
 27 W LEFT ON TINGEN RD LEFT INTO
 PATTONS POINT LEFT ONTO BUNKER BUSTER
 R ONTO FIFTY CALIBER R ONTO EISENHOWER
 CT LOT 68

STRUCTURE: 000 000 68X52 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/01/12	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002233675
	6/01/12	AP	T/S: 06/01/2012 10:59 AM DETAYLOR -----
B103 01	6/15/12	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002240140
	6/15/12	AP	T/S: 06/15/2012 12:43 PM MREARIC -----
A814 01	6/20/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002240159
	6/22/12	AP	45 EISENHOWER CT LOT 68 BROADWAY 27505----- T/S: 06/22/2012 09:34 AM TWARD -----
B105 01	9/25/12	MR	R*OPEN FLOOR VRU #: 002282381
	9/25/12	AP	T/S: 09/25/2012 01:58 PM MREARIC -----
R425 01	10/19/12	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002293066
	10/19/12	DA	T/S: 10/19/2012 01:14 PM MREARIC ----- 1. install a strap at every other stud on hinge wall in master bedroom or baloon frame it per code 2. install flashing at floor on porch
I129 01	10/25/12	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002295681
	10/25/12	AP	T/S: 10/25/2012 12:45 PM MREARIC -----
R425 02	10/25/12	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002295665
	10/25/12	AP	T/S: 10/25/2012 12:45 PM MREARIC -----
H824 01	2/28/13	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002347268
	2/28/13	AP	T/S: 03/05/2013 08:11 AM SSTEWARD ----- T/S: 03/05/2013 08:11 AM SSTEWARD -----
R429 01	4/16/13	MR	FOUR TRADE FINAL TIME: 17:00 VRU #: 002367001
	4/16/13	DA	2013 01:14 PM MREARIC ----- attic door not stripped or correct material
R429 02	4/19/13	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002369650
			T/S: 04/18/2013 01:37 PM DJOHNSON -----

----- COMMENTS AND NOTES -----

ADDRESS : 45 EISENHOWER CT SUBDIV: PATTONS POINT
 CONTRACTOR : ISRAEL LUCAS CONSTRUCTION INC PHONE : (919) 770-0902
 OWNER : ISRAEL LUCAS CONST INC PHONE : (919) 770-0902
 PARCEL : 03-9597- - -0039- -63-
 APPL NUMBER: 12-50028874 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 05/03/2012 11:09 AM JBROCK ----
 27 W LEFT ON TINGEN RD LEFT INTO
 PATTONS POINT LEFT ONTO BUNKER BUSTER
 R ONTO FIFTY CALIBER R ONTO EISENHOWER
 CT LOT 68

STRUCTURE: 000 000 68X52 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/01/12	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002233675
	6/01/12	AP	T/S: 06/01/2012 10:59 AM DETAYLOR -----
B103 01	6/15/12	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002240140
	6/15/12	AP	T/S: 06/15/2012 12:43 PM MREARIC -----
A814 01	6/20/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002240159
	6/22/12	AP	45 EISENHOWER CT LOT 68 BROADWAY 27505----- T/S: 06/22/2012 09:34 AM TWARD -----
B105 01	9/25/12	MR	R*OPEN FLOOR VRU #: 002282381
	9/25/12	AP	T/S: 09/25/2012 01:58 PM MREARIC -----
R425 01	10/19/12	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002293066
	10/19/12	DA	T/S: 10/19/2012 01:14 PM MREARIC ----- 1. install a strap at every other stud on hinge wall in master bedroom or baloon frame it per code 2. install flashing at floor on porch
I129 01	10/25/12	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002295681
	10/25/12	AP	T/S: 10/25/2012 12:45 PM MREARIC -----
R425 02	10/25/12	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002295665
	10/25/12	AP	T/S: 10/25/2012 12:45 PM MREARIC -----
H824 01	2/28/13	OT	ENVIR OPERATIONS PERMIT TIME: 17:00 VRU #: 002347268
	2/28/13	AP	T/S: 03/05/2013 08:11 AM SSTEWARD ----- T/S: 03/05/2013 08:11 AM SSTEWARD -----
R429 01	4/16/13	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002367001

4-16-13 DA-MR

COMMENTS AND NOTES

Attic Door + weather-stopping