Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated:
Proposed Facility: 3 BR 2000m Design Flow (.1949): 360 gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-16	G S	VFR NS/NP					
		16-44"	G SL	FR SS/NP					
		44"+	SBK SCL	FR SS/P	10YR 7/2 @ 44"				PS .5
2		0-10	G S	VFR NS/NP					
		10-35	G SL	FR SS/NP					
		35"	SBK SCL	FR SS/P	10YR 7/2 @ 40"				PS .5
3		0-25	G S	VFR NS/NP					
		25-44"	G SL	FR SS/NP					S .6

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	25%	25% Pump
Site LTAR	.5	.6

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: OT
Others Present: BM