

ADDRESS : 539 LAFAYETTE RD SUBDIV:
 CONTRACTOR : DAWSON'S CONSTRUCTION, LLC PHONE : (919) 201-3841
 OWNER : DAWSONS CONSTRUCTION LLC PHONE : (919) 201-3841
 PARCEL : 08-0653- - -0118- -06-
 APPL NUMBER: 12-50028879 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 05/07/2012 08:23 AM JBROCK ----
 FROM LILLINGTON TAKE 401 N TOWARD F-VAR
 TURN R ON LAFAYETTE RD GO PAST
 LAFAYETTE ELE AND LOT IS ON LEFT
 PRE # 74321415

STRUCTURE: 000 000 58X45.4 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/05/12	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002235208
	6/12/12	AP	T/S: June 12, 2012 08:08 AM BSUTTON -----
B103 01	6/12/12	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002238566
	6/12/12	AP	T/S: 06/11/2012 03:03 PM DJOHNSON ----- T/S: June 12, 2012 08:08 AM BSUTTON -----
A814 01	6/14/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002239572
	6/21/12	AP	T/S: 06/13/2012 01:48 PM VBROWN ----- 539 Lafayette Rd fuquay varina 27526 T/S: 06/21/2012 10:35 AM TWARD -----
B105 01	6/14/12	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 002239598
	6/14/12	AE	T/S: 06/13/2012 01:48 PM VBROWN ----- Open floor ok pending engineers letter on changes to framing.
R425 01	7/10/12	BS	FOUR TRADE ROUGH IN VRU #: 002249775
	7/10/12	CA	T/S: July 10, 2012 08:08 AM BSUTTON -----
R425 02	7/11/12	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002250546
	7/11/12	DA	T/S: 07/10/2012 02:35 PM VBROWN ----- Support top of Valleys to load walls below or have engineer specify a valley to ridge / valley to valley connector.
I129 01	7/17/12	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002252583
	7/17/12	AP	T/S: July 17, 2012 09:37 AM BSUTTON -----
R425 03	7/17/12	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002252575
	7/17/12	AP	T/S: July 17, 2012 09:37 AM BSUTTON -----
H824 01	8/09/12	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002263598
	8/09/12	AP	T/S: 08/09/2012 11:21 AM SSTEWARD ----- T/S: 08/09/2012 11:21 AM SSTEWARD -----
E209 01	8/30/12	BS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002272888
	8/30/12	AP	T/S: August 30, 2012 11:22 AM BSUTTON ----- Need a receptacle under house at final. Temp power approved
R429 01	9/20/12	TI	FOUR TRADE FINAL VRU #: 002280748

9/20/12 DAB

COMMENTS AND NOTES