

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:

Address:  
 Proposed Facility: 5 bedrooms

Date Evaluated: 5/2/12  
 Design Flow (.1949): 600 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public     Individual     Well

Spring     Other

Evaluation Method:  Auger Boring

Pit     Cut

Type of Wastewater:

Sewage     Industrial Process     Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Witness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5%	0-30	GS	VFR NS/NP					
		30-44	SBK SCL	FR SS/SF					PS S3
		44-58	SBK SCL	FR S/SF	10YR 7/2 @ 44"				
		58-70	SBK SCL	FR SS/SF					
2		0-30	GS	VFR NS/NP					
		30-48	SBK SCL	FR SS/SF	10YR 7/2 @ 44"				PS S3
3		0-22	GS	VFR NS/NP					
		22-36	SBK SCL	FR SS/SF					PS S3
		36"	GS	VFR NS/NP					

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input type="checkbox"/>	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: RA Others Present: BM
Available Space (.1945)			
System Type(s)	257/260	PANEL	
Site LTAR	.S3	.S3	