

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949): 480 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public Individual Well

Spring Other

Evaluation Method:

Auger Boring Pit Cut

Type of Wastewater:

Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7	0-14	G LS	VF ₂ vs/np					
		14-48	SBX SCL	F ₂ ss/np	10YR2/2e 38"				PS .5
2		0-24"	G LS	VF ₂ vs/np					
		24-48"	SBX SCL	F ₂ ss/np	10YR2/2e 40"				PS .5

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: RS Others Present: 1
Available Space (.1945)	✓	✓	
System Type(s)	PUMP 25% RSD		
Site LTAR	.5	.5	