

ADDRESS : 140 TRIPP RD
CONTRACTOR : GREGORY INC
OWNER : POWELL WILLIAM AND KATHY
PARCEL : 11-0661- - -0038- -05-
APPL NUMBER: 12-50028951 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 05/16/2012 10:58 AM JBROCK ----
GO N ON 210 LEFT ON TRIPP RD 2ND
HOMESITE ON RIGHT

SUBDIV:
PHONE : (919) 639-6101
PHONE : (919) 576-7460

STRUCTURE: 000 000 75X65 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3000000.00

SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/08/12	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002237618
	6/08/12	AP	T/S: 06/08/2012 08:18 AM VBROWN ----- T/S: June 08, 2012 11:09 AM BSUTTON -----
B101 02	6/15/12	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002239770
	6/15/12	AP	T/S: 06/14/2012 08:01 AM VBROWN ----- Footing to change rear porch from wood to masonry-----
A814 01	6/18/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002240406
	6/22/12	AP	T/S: 06/15/2012 09:27 AM VBROWN ----- 140 TRIPP RD LILLINGTON 27546 T/S: 06/22/2012 09:29 AM TWARD -----
B103 01	6/18/12	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002240398
	6/18/12	AP	T/S: 06/15/2012 09:27 AM VBROWN ----- T/S: 06/19/2012 10:02 AM DETAYLOR -----
B105 01	6/22/12	DT	R*OPEN FLOOR VRU #: 002242647
	6/22/12	AP	T/S: 06/22/2012 01:27 PM DETAYLOR -----
R427 01	7/19/12	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002254068
	7/19/12	DA	T/S: 07/18/2012 12:24 PM VBROWN ----- T/S: 07/19/2012 04:08 PM KSLATTUM ----- 1. Need approved air barriers behind tub and shower. Make sure it is properly fastened and sealed. 2. Plan calls for 3 jacks under header for rear french door. 3. Seal around osb above fire place. 4. Need fire caulking for electrical wire at top plate at door from laundry room. 5. windows shall have a ufactor of .35 for current code. You have .36 installed. 6. Need receptacle accessible from grade on rear of house. 7. Need to install flashing for brick veneer beneath house wrap. 8. No gasket or seal on bottom plat to floor. Note: 4/0 can only be used if no additional load is taken off at meter base.
R427 02	7/24/12	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002255586
	7/24/12	AE	T/S: 07/23/2012 09:11 AM VBROWN ----- T/S: 07/24/2012 01:18 PM KSLATTUM ----- Windows to be inspected at final. Ok to insulate and brick.
I129 01	7/26/12	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002257053
	7/26/12	AP	T/S: 07/25/2012 07:58 AM VBROWN ----- T/S: 07/26/2012 01:11 PM KSLATTUM -----
H824 01	9/05/12	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002275378

----- CONTINUED ONTO NEXT PAGE -----

PREPARED 10/18/12, 14:14:06
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 23
DATE 10/19/12

ADDRESS : 140 TRIPP RD
CONTRACTOR : GREGORY INC
OWNER : POWELL WILLIAM AND KATHY
PARCEL : 11-0661- - -0038- -05-
APPL NUMBER: 12-50028951 CP NEW RESIDENTIAL (SFD)

SUBDIV:
PHONE : (919) 639-6101
PHONE : (919) 576-7460

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	9/05/12	AP	T/S: 09/06/2012 10:24 AM SSTEWARD -----
			T/S: 09/06/2012 10:24 AM SSTEWARD -----
E209 01	10/12/12	BS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002290237
	10/12/12	DA	T/S: 10/11/2012 11:10 AM VBROWN -----
			T/S: October 12, 2012 02:18 PM BSUTTON -----
			Light/receptacle missing in attic. 2. Switch for attic unit not wired. 3. Neutral ground bonded in subpanel. 4. Receptacle missing near entrance to first bedroom on left (from kitchen) between entry door and closet door.
E209 02	10/16/12	BS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002291177
	10/16/12	AP	T/S: 10/15/2012 08:25 AM VBROWN -----
			T/S: October 16, 2012 01:45 PM BSUTTON -----
			Approved for power. Still need receptacle in bedroom and smoke detector outside of master bedroom before final
R429 01	10/19/12	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002293017

10-19

DA

----- COMMENTS AND NOTES -----

PREPARED 10/15/12, 13:57:16
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 3
DATE 10/16/12

ADDRESS : 140 TRIPP RD
CONTRACTOR : GREGORY INC
OWNER : POWELL WILLIAM AND KATHY
PARCEL : 11-0661- - -0038- -05-
APPL NUMBER: 12-50028951 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 05/16/2012 10:58 AM JBROCK ----
GO N ON 210 LEFT ON TRIPP RD 2ND
HOMESITE ON RIGHT

SUBDIV:
PHONE : (919) 639-6101
PHONE : (919) 576-7460

06/25773

STRUCTURE: 000 000 75X65 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3000000.00

SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/08/12	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002237618
	6/08/12	AP	T/S: 06/08/2012 08:18 AM VBROWN ----- T/S: June 08, 2012 11:09 AM BSUTTON -----
B101 02	6/15/12	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002239770
	6/15/12	AP	T/S: 06/14/2012 08:01 AM VBROWN ----- Footing to change rear porch from wood to masonry-----
A814 01	6/18/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002240406
	6/22/12	AP	T/S: 06/15/2012 09:27 AM VBROWN ----- 140 TRIPP RD LILLINGTON 27546 T/S: 06/22/2012 09:29 AM TWARD -----
B103 01	6/18/12	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002240398
	6/18/12	AP	T/S: 06/15/2012 09:27 AM VBROWN ----- T/S: 06/19/2012 10:02 AM DETAYLOR -----
B105 01	6/22/12	DT	R*OPEN FLOOR VRU #: 002242647
	6/22/12	AP	T/S: 06/22/2012 01:27 PM DETAYLOR -----
R427 01	7/19/12	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002254068
	7/19/12	DA	T/S: 07/18/2012 12:24 PM VBROWN ----- T/S: 07/19/2012 04:08 PM KSLATTUM ----- 1. Need approved air barriers behind tub and shower. Make sure it is properly fastened and sealed. 2. Plan calls for 3 jacks under header for rear french door. 3. Seal around osb above fire place. 4. Need fire caulking for electrical wire at top plate at door from laundry room. 5. windows shall have a ufactor of .35 for current code. You have .36 installed. 6. Need receptacle accessible from grade on rear of house. 7. Need to install flashing for brick veneer beneath house wrap. 8. No gasket or seal on bottom plat to floor. Note: 4/0 can only be used if no additional load is taken off at meter base.
R427 02	7/24/12	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002255586
	7/24/12	AE	T/S: 07/23/2012 09:11 AM VBROWN ----- T/S: 07/24/2012 01:18 PM KSLATTUM ----- Windows to be inspected at final. Ok to insulate and brick.
I129 01	7/26/12	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002257053
	7/26/12	AP	T/S: 07/25/2012 07:58 AM VBROWN ----- T/S: 07/26/2012 01:11 PM KSLATTUM -----
H824 01	9/05/12	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002275378

CONTINUED ONTO NEXT PAGE

PREPARED 10/15/12, 13:57:16
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 4
DATE 10/16/12

ADDRESS : 140 TRIPP RD
CONTRACTOR : GREGORY INC
OWNER : POWELL WILLIAM AND KATHY
PARCEL : 11-0661- - -0038- -05-
APPL NUMBER: 12-50028951 CP NEW RESIDENTIAL (SFD)

SUBDIV:
PHONE : (919) 639-6101
PHONE : (919) 576-7460

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	9/05/12	AP	T/S: 09/06/2012 10:24 AM SSTEWARD ----- T/S: 09/06/2012 10:24 AM SSTEWARD -----
E209 01	10/12/12	BS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002290237
	10/12/12	DA	T/S: 10/11/2012 11:10 AM VBROWN ----- T/S: October 12, 2012 02:18 PM BSUTTON ----- Light/receptacle missing in attic. 2. Switch for attic unit not wired. 3. Neutral ground bonded in subpanel. 4. Receptacle missing near entrance to first bedroom on left (from kitchen) between entry door and closet door.
E209 02	10/16/12	TI	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002291177
	<u>10/16/12</u>	<u>APBS</u>	T/S: 10/15/2012 08:25 AM VBROWN -----

----- COMMENTS AND NOTES -----

PREPARED 10/11/12, 14:34:08
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 13
DATE 10/12/12

ADDRESS : 140 TRIPP RD
CONTRACTOR : GREGORY INC
OWNER : POWELL WILLIAM AND KATHY
PARCEL : 11-0661- - -0038- -05-
APPL NUMBER: 12-50028951 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 05/16/2012 10:58 AM JBROCK ----
GO N ON 210 LEFT ON TRIPP RD 2ND
HOMESITE ON RIGHT

SUBDIV:
PHONE : (919) 639-6101
PHONE : (919) 576-7460

STRUCTURE: 000 000 75X65 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3000000.00

SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/08/12	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002237618
	6/08/12	AP	T/S: 06/08/2012 08:18 AM VBROWN ----- T/S: June 08, 2012 11:09 AM BSUTTON -----
B101 02	6/15/12	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002239770
	6/15/12	AP	T/S: 06/14/2012 08:01 AM VBROWN ----- Footing to change rear porch from wood to masonry-----
A814 01	6/18/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002240406
	6/22/12	AP	T/S: 06/15/2012 09:27 AM VBROWN ----- 140 TRIPP RD LILLINGTON 27546 T/S: 06/22/2012 09:29 AM TWARD -----
B103 01	6/18/12	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002240398
	6/18/12	AP	T/S: 06/15/2012 09:27 AM VBROWN ----- T/S: 06/19/2012 10:02 AM DETAYLOR -----
B105 01	6/22/12	DT	R*OPEN FLOOR VRU #: 002242647
	6/22/12	AP	T/S: 06/22/2012 01:27 PM DETAYLOR -----
R427 01	7/19/12	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002254068
	7/19/12	DA	T/S: 07/18/2012 12:24 PM VBROWN ----- T/S: 07/19/2012 04:08 PM KSLATTUM ----- 1. Need approved air barriers behind tub and shower. Make sure it is properly fastened and sealed. 2. Plan calls for 3 jacks under header for rear french door. 3. Seal around osb above fire place. 4. Need fire caulking for electrical wire at top plate at door from laundry room. 5. windows shall have a ufactor of .35 for current code. You have .36 installed. 6. Need receptacle accessible from grade on rear of house. 7. Need to install flashing for brick veneer beneath house wrap. 8. No gasket or seal on bottom plat to floor. Note: 4/0 can only be used if no additional load is taken off at meter base.
R427 02	7/24/12	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002255586
	7/24/12	AE	T/S: 07/23/2012 09:11 AM VBROWN ----- T/S: 07/24/2012 01:18 PM KSLATTUM ----- Windows to be inspected at final. Ok to insulate and brick.
I129 01	7/26/12	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002257053
	7/26/12	AP	T/S: 07/25/2012 07:58 AM VBROWN ----- T/S: 07/26/2012 01:11 PM KSLATTUM -----
H824 01	9/05/12	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002275378

CONTINUED ONTO NEXT PAGE

PREPARED 10/11/12, 14:34:08
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 14
DATE 10/12/12

ADDRESS : 140 TRIPP RD
CONTRACTOR : GREGORY INC
OWNER : POWELL WILLIAM AND KATHY
PARCEL : 11-0661- - -0038- -05-
APPL NUMBER: 12-50028951 CP NEW RESIDENTIAL (SFD)

SUBDIV:
PHONE : (919) 639-6101
PHONE : (919) 576-7460

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	9/05/12	AP	T/S: 09/06/2012 10:24 AM SSTEWARD -----
			T/S: 09/06/2012 10:24 AM SSTEWARD -----
E209 01	10/12/12	TN	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002290237
	<u>10-12-12</u>	<u>DABS</u>	T/S: 10/11/2012 11:10 AM VBROWN -----

----- COMMENTS AND NOTES -----